

## **Assessment of application against relevant Development Codes**

### **APPLICATION DETAILS**

<b>APPLICATION</b>		<b>PREMISES</b>	
<b>FILE NO:</b>	MCU/18/0002	<b>ADDRESS:</b>	45-51 Raleigh Street, Dimbulah
<b>APPLICANT:</b>	O Davies	<b>RPD:</b>	Lot 505 on HG727 and Lots 506 - 508 on HG714
<b>LODGED BY:</b>	O Davies	<b>AREA:</b>	Lot 505 - 506m <sup>2</sup> Lot 506 - 615m <sup>2</sup> Lot 505 - 537m <sup>2</sup> Lot 508 - 569m <sup>2</sup>
<b>DATE LODGED:</b>	17 January 2018	<b>OWNER:</b>	O Davies
<b>TYPE OF APPROVAL:</b>	Development Permit		
<b>PROPOSED DEVELOPMENT:</b>	Material Change of Use - Community Use (Museum)		
<b>PLANNING SCHEME:</b>	Mareeba Shire Council Planning Scheme 2016		
<b>ZONE:</b>	Centre		
<b>LEVEL OF ASSESSMENT:</b>	Code assessment		
<b>SUBMISSIONS:</b>	N/A - Code assessment only		

### **Relevant Development Codes**

The following Development Codes are considered to be applicable to the assessment of the application:

- 6.2.1 Centre zone code
- 9.3.3 Community activities code
- 9.4.2 Landscaping code
- 9.4.3 Parking and access code
- 9.4.5 Works, services and infrastructure code

### 6.2.1 Centre zone code

#### 6.2.1.1 Application

- (1) This code applies to assessing development where:
  - (a) located in the Centre zone; and
  - (b) it is identified in the assessment benchmarks for assessable development and requirements for accepted development column of an assessment table in Part 5 of the planning scheme.

#### 6.2.1.2 Purpose

- (1) The purpose of the Centre zone code is to provide for a mix of uses and activities.

These uses include, but are not limited to, business, retail, professional, administrative, community, entertainment, cultural and residential activities.

Centres are found at a variety of scales based on their location and surrounding activities.

- (2) Mareeba Shire Council's purpose of the Centre zone code is to facilitate the orderly development of the network of centres to meet the needs of the communities throughout the shire.
- (3) The purpose of the code will be achieved through the following overall outcomes:
  - (a) Promotion of a mix of commercial, business, professional, accommodation and retail activities;
  - (b) Industries such as service and low impact industries may be appropriate where they are for the provision of trade, service or light industries that are of a compatible scale with commercial activities and preferably do not adjoin residential areas;
  - (c) Residential development is facilitated where it can integrate and enhance the fabric of the centre and is located behind or above commercial development;
  - (d) Development provides a high level of amenity and is reflective of the surrounding character of the area;
  - (e) Development is generally established in accessible, well-connected locations with access or future access to public transport, cycling and pedestrian networks;
  - (f) Development does not compromise the viability of the hierarchy and network of activity centres, namely:
    - (i) Mareeba as a major regional activity centre, which accommodates the most significant concentrations of regional-scale business, retail, entertainment, government administration, secondary and tertiary educational facilities and health and social services within the shire;
    - (ii) Kuranda as a village activity centre, which accommodates services, arts and cultural facilities, sports and recreation facilities, business and employment uses to support the village and its constituent surrounding rural and rural residential communities;
    - (iii) Chillagoe and Dimbulah as Rural activity centres, which provide commercial and community services to their rural catchments; and
    - (iv) Bibohra, Irvinebank, Julatten, Koah, Mutchilba, Mt Molloy, Myola and Speewah as rural villages, that have limited centre activities and other non-residential activities.

### 6.2.1.3 Criteria for assessment

**Table 6.2.1.3A—Centre zone code - For accepted development subject to requirements and assessable development**

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>For accepted development subject to requirements and assessable development</b>			
<b>Height</b>			
<b>PO1</b> Building height takes into consideration and respects the following: <ul style="list-style-type: none"> <li>(a) the height of existing buildings on adjoining premises;</li> <li>(b) the development potential, with respect to height, on adjoining premises;</li> <li>(c) the height of buildings in the vicinity of the site;</li> <li>(d) access to sunlight and daylight for the site and adjoining sites;</li> <li>(e) privacy and overlooking; and</li> <li>(f) site area and street frontage length.</li> </ul>	<b>AO1</b> Development has a maximum building height of: <ul style="list-style-type: none"> <li>(a) 8.5 metres; and</li> <li>(b) 2 storeys above ground level.</li> </ul>	✓	Complies.
<b>Siting</b>			
<b>PO2</b> Development is sited in a manner that considers and respects: <ul style="list-style-type: none"> <li>(a) the siting and use of adjoining premises;</li> <li>(b) access to sunlight and daylight for the site and adjoining sites;</li> <li>(c) privacy and overlooking;</li> <li>(d) opportunities for casual surveillance of adjoining public spaces;</li> <li>(e) air circulation and</li> </ul>	<b>AO2.1</b> Buildings are built to the road frontage/s of the site.  Note—Awning structures may extend into the road reserve where provided in accordance with <b>PO5</b> .	✓ Complies with PO2	

Performance outcomes		Acceptable outcomes	Complies	Comments
(f)	access to natural breezes;	<b>AO2.2</b> Buildings are setback and boundary treatment(s) are undertaken in accordance with <b>Table 6.2.1.3B</b> .	✓	Despite not achieving the 0 metre setback to side and rear boundaries as required by AO2.2, the larger setbacks provided could only further minimise amenity impacts on the rear adjoining property, which although zoned Centre, contains a sensitive land use (dwelling). Solid screen fencing will be conditioned along the rear or northern boundary.
(g)	appearance of building bulk; and relationship with pedestrian spaces.			
Accommodation density				
<b>PO3</b> The density of Accommodation activities:	<b>AO3</b> Development provides a maximum density for Accommodation activities of:	n/a	Not applicable - the proposed development does not involve an accommodation component.	
(a) contributes to housing choice and affordability;	(a) 1 dwelling or accommodation unit per 120m <sup>2</sup> site area; and			
(b) respects the nature and density of surrounding land use;	(b) 1 bedroom per 60m <sup>2</sup> site area.			
(c) does not cause amenity impacts beyond the reasonable expectation of the planned accommodation density for the centre; and				
(d) is commensurate to the scale and frontage of the site.				

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>Site cover</b>			
<b>PO4</b> Buildings and structures occupy the site in a manner that: <ul style="list-style-type: none"> <li>(a) makes efficient use of land;</li> <li>(b) is consistent with the bulk and scale of surrounding buildings; and</li> <li>(c) appropriately balances built and natural features.</li> </ul>	<b>AO4</b> Site cover does not exceed 90%.	✓	Complies.
<b>For assessable development</b>			
<b>Building design</b>			
<b>PO5</b> Building facades are appropriately designed to: <ul style="list-style-type: none"> <li>(a) provide an active and vibrant streetscape;</li> <li>(b) include visual interest and architectural variation;</li> <li>(c) maintain and enhance the character of the surrounds;</li> <li>(d) provide opportunities for casual surveillance;</li> <li>(e) include a human scale; and</li> <li>(f) encourage occupation of outdoor space.</li> </ul>	<b>AO5.1</b> Buildings address and provide pedestrian entrances to: <ul style="list-style-type: none"> <li>(a) the primary pedestrian frontage where a single frontage lot or multiple frontage lot that is not a corner lot;</li> <li>(b) the primary and secondary frontages where a corner lot, with a pedestrian entrance provided on each frontage and/or as part of a corner truncation; and</li> <li>(c) any adjoining public place, with the main entrance provided on this boundary.</li> </ul>	✓	Complies where relevant.

Performance outcomes	Acceptable outcomes	Complies	Comments
	<b>AO5.2</b> Building frontages: (a) are broken into smaller, 10 metre wide components by doors, display windows, pillars and structural elements; (b) are articulated with projections and recesses; (c) include windows where the bottom of the window is located between 0.6 metres and 0.9 metres above the footpath level; and (d) have a minimum 40% of the building facade facing the street is comprised of windows that are not painted or treated to obscure transparency.	✓	Complies - See site plan. The structures proposed are detached.
	<b>AO5.3</b> Buildings incorporate cantilevered awnings that are: (a) provided along the full length of the building's frontage to the street; (b) set back 0.6 metres from the face of the kerb or to match the alignment of the awning/s of the adjoining building/s; (c) a minimum of 3 metres and a maximum of 4.2 metres above the finished level of the footpath from the underside of the awning; and (d) truncated at the corner with a 2 metre single cord truncation where located on a corner site.	n/a	Not applicable considering the nature and scale of the development.

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>PO6</b> Development complements and integrates with the established built character of the Centre zone, having regard to: (a) roof form and pitch; (b) eaves and awnings; (c) building materials, colours and textures; and (d) window and door size and location.	<b>AO6</b> No acceptable outcome is provided.	✓	Complies with PO6.
<b>Accommodation activities</b>			
<b>PO7</b> Accommodation activities are appropriately located in buildings in the Centre zone, having regard to: (a) the use of adjoining premises; and (b) the provision of an active and vibrant streetscape.	<b>AO7</b> Accommodation activities are located above the ground floor.	n/a	Not applicable - No accommodation activities are proposed.
<b>Amenity</b>			
<b>PO8</b> Development must not detract from the amenity of the local area, having regard to: (a) noise; (b) hours of operation; (c) traffic; (d) advertising devices; (e) visual amenity; (f) privacy; (g) lighting; (h) odour; and (i) emissions.	<b>AO8</b> No acceptable outcome is provided.	✓	The development will be conditioned to ensure minimal impact on adjoining residential land uses.

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>PO9</b> Development must take into account and seek to ameliorate any existing negative environmental impacts, having regard to: <ul style="list-style-type: none"> <li>(a) noise;</li> <li>(b) hours of operation;</li> <li>(c) traffic;</li> <li>(d) advertising devices;</li> <li>(e) visual amenity;</li> <li>(f) privacy;</li> <li>(g) lighting;</li> <li>(h) odour; and</li> <li>(i) emissions.</li> </ul>	<b>AO9</b> No acceptable outcome is provided.	n/a	Not applicable - No known negative environmental impacts originate from the subject land.

**Table 6.2.1.3B—Setbacks and treatments to side and rear boundaries**

Design	Where adjoining land in the Low density residential zone, the Medium density residential zone or the Rural residential zone	Where including windows facing the side boundary	All other instances
Building and structure setback	2 metres	1 metre	0 metres
Boundary treatment	<ul style="list-style-type: none"> <li>• Landscape strip with a minimum width of 1.5 metres; and</li> <li>• 1.8 metre high solid screen fence</li> </ul>	Screening to windows where required to prevent overlooking or privacy impacts	Blank wall including low maintenance finishes and materials

### 9.3.3 Community activities code

#### 9.3.3.1 Application

- (1) This code applies to assessing development where:
  - (a) involving Community activities; and
  - (b) it is identified in the assessment benchmarks for assessable development and requirements for accepted development column of an assessment table in Part 5 of the planning scheme.

#### 9.3.3.2 Purpose

- (1) The purpose of the Community activities code is to ensure Community activities that are appropriately designed and located to:
  - (a) be conveniently accessible to the communities they serve; and
  - (b) not detrimentally impact on local amenity.
- (2) The purpose of the code will be achieved through the following overall outcomes:
  - (a) Community activities do not have an adverse impact on the amenity of the surrounding area;
  - (b) Community activities establish in appropriate locations that are highly accessible;
  - (c) Community activities are located with other community activities when the opportunity to achieve practical co-location of facilities exists;
  - (d) Community activities are designed to be accessible, functional and safe;
  - (e) Community activities are compatible and integrated with surrounding land uses; and
  - (f) Community activities enhance community identity and character.

#### 9.3.3.3 Criteria for assessment

**Table 9.3.3.3—Community activities code - For accepted development subject to requirements and assessable development**

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>For accepted development subject to requirements and assessable development</b>			
<b>Amenity and privacy</b>			
<b>PO1</b> Community activities are appropriately located and designed to avoid adverse impacts on sensitive uses related to: <ol style="list-style-type: none"><li>(a) noise;</li><li>(b) lighting; and</li><li>(c) overlooking.</li></ol> Note—These provisions apply to any adjoining sensitive use, both on an adjoining site and on the same site as the Community activity.	<b>AO1</b> Along any common boundary with a sensitive land use, development incorporates: <ol style="list-style-type: none"><li>(a) a 1.8 metre high solid screen fence; and</li><li>(b) screening to windows which:<ol style="list-style-type: none"><li>(i) face the boundary;</li><li>(ii) have a sill height less than 1.5 metres; and</li><li>(iii) are not wholly screened by the boundary fence.</li></ol></li></ol>	✓	Will be conditioned to comply along the northern boundary of the subject land.

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>If for Educational establishment or Child care centre</b>			
<b>PO2</b> Development is located on a site that is capable of accommodating: (a) all facilities necessary for the use; (b) required landscaping and buffering; and (c) appropriately designed access, manoeuvring and parking areas.	<b>AO2</b> The development is located on a site with a minimum: (a) site area of 800m <sup>2</sup> ; (b) road frontage of 20 metres; and (c) road reserve width of 20 metres.	✓	Although each of the 4 individual lots are less than 800m <sup>2</sup> , the subject land has a cumulative area of 2,227m <sup>2</sup> and is considered to comply with PO2 as it provides adequate space for the proposed development.
<b>PO3</b> The design of the development does not result in any safety hazard for children or other users of the facility.	<b>AO3</b> A child proof fence or physical barrier is provided to prevent unintended access to the following areas, directly from indoor or outdoor areas intended to accommodate children: (a) Vehicle manoeuvring and parking areas; (b) Refuse storage and servicing areas; and (c) Air conditioning, refrigeration plant and mechanical plant.	✓	Can be conditioned to comply where relevant.
<b>For assessable development</b>			
<b>Location</b>			
<b>AO4</b> Development is compatible with the amenity of the surrounding area, having regard to: (a) the location and type of vehicular access and parking; (b) hours of operation; (c) waste storage and collection; (d) advertising devices and signage; (e) visual amenity; (f) privacy; and (g) noise, odour and dust emissions.	<b>AO4</b> No acceptable outcome is provided.	✓	Complies.

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>PO5</b> Community activities are highly accessible to the community they serve and are located to encourage multi-purpose trips.	<b>AO5.1</b> Community activities are not located in a cul-de-sac.	✓	Complies.
	<b>AO5.2</b> Development is located: (a) within 800 metres walking distance of the Centre zone; or (b) within 400 metres walking distance of a public transport stop; or (c) provided with a connection to the pedestrian and cycle network.	✓	Complies.
<b>Amenity and privacy</b>			
<b>PO6</b> Community activities protect and enhance the character and amenity of the locality and streetscape through the appropriate location and screening of: (a) air conditioning; (b) refrigeration plant; (c) mechanical plant; and (d) refuse bin storage areas.	<b>AO6</b> No acceptable outcome is provided.	✓	Will be conditioned to comply where relevant.
<b>If for Educational establishment or Child care centre</b>			
<b>PO7</b> Educational establishments and Child care centres: (a) do not detrimentally impact on the amenity or operations of surrounding land uses; and (b) have suitable separation distances and buffering from sensitive uses.	<b>AO7</b> No acceptable outcome is provided.	n/a	Not applicable.

## 9.4.2 Landscaping code

### 9.4.2.1 Application

This code applies where it is identified in the assessment benchmarks for assessable development and requirements for accepted development column of an assessment table in Part 5 of the planning scheme.

### 9.4.2.2 Purpose

- (1) The purpose of the Landscaping code is to ensure all development is landscaped to a standard that:
  - (a) complements the scale and appearance of the development;
  - (b) protects and enhances the amenity and environmental values of the site;
  - (c) complements and enhances the streetscape and local landscape character; and
  - (d) ensures effective buffering of incompatible land uses to protect local amenity.
- (2) The purpose of the code will be achieved through the following overall outcomes:
  - (a) Landscaping is a functional part of development design and is commensurate with the intended use;
  - (b) Landscaping accommodates the retention of existing significant on site vegetation where appropriate and practical;
  - (c) Landscaping treatments complement the scale, appearance and function of the development;
  - (d) Landscaping contributes to an attractive streetscape;
  - (e) Landscaping enhances the amenity and character of the local area;
  - (f) Landscaping enhances natural environmental values of the site and the locality;
  - (g) Landscaping provides effective screening both on site, if required, and between incompatible land uses;
  - (h) Landscaping provides shade in appropriate circumstances;
  - (i) Landscape design enhances personal safety and reduces the potential for crime and vandalism; and
  - (j) Intensive land uses incorporate vegetated buffers to provide effective screening of buildings, structures and machinery associated with the use.

### 9.4.2.3 Criteria for assessment

**Table 9.4.2.3A—Landscaping code - For accepted development subject to requirements and assessable development**

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>For accepted development subject to requirements and assessable development</b>			
<b>PO1</b> Development, other than in the Rural zone, includes landscaping that: <ul style="list-style-type: none"> <li>(a) contributes to the landscape character of the Shire;</li> <li>(b) compliments the character of the immediate surrounds;</li> <li>(c) provides an appropriate balance between built and natural elements; and</li> <li>(d) provides a source of visual interest.</li> </ul>	<b>AO1</b> Development, other than in the Rural zone, provides: <ul style="list-style-type: none"> <li>(a) a minimum of 10% of the site as landscaping;</li> <li>(b) planting in accordance with Planning Scheme Policy 6 - Landscaping and preferred plant species;</li> <li>(c) for the integration of retained significant vegetation into landscaping areas;</li> <li>(d) on-street landscaping works in accordance with the Design Guidelines set out in Section D9 Landscaping, of the Planning Scheme Policy 4 - FNQROC Regional Development Manual.</li> </ul> <p>Note—Where development exceeds a site cover of 90%, areas of landscaping may be provided above ground level to achieve a total supply of landscaping equivalent to 10% of the site area.</p>	✓	Can be conditioned to comply.

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>PO2</b> Development, other than in the Rural zone, includes landscaping along site frontages that: <ul style="list-style-type: none"> <li>(a) creates an attractive streetscape;</li> <li>(b) compliments the character of the immediate surrounds;</li> <li>(c) assists to break up and soften elements of built form;</li> <li>(d) screen areas of limited visual interest or servicing;</li> <li>(e) provide shade for pedestrians; and</li> <li>(f) includes a range and variety of planting.</li> </ul>	<b>AO2</b> Development, other than in the Rural zone, includes a landscape strip along any site frontage: <ul style="list-style-type: none"> <li>(a) with a minimum width of 2 metres where adjoining a car parking area;</li> <li>(b) with a minimum width of 1.5 metres in all other locations; and</li> <li>(c) in accordance with Planning Scheme Policy 6 - Landscaping and preferred plant species.</li> </ul> <p>Note—Where development is setback from a frontage less than 1.5 metres, the setback area is provided as a landscape strip</p>	✓	Can be conditioned to comply where relevant.
<b>PO3</b> Development includes landscaping and fencing along side and rear boundaries that: <ul style="list-style-type: none"> <li>(a) screens and buffer land uses;</li> <li>(b) assists to break up and soften elements of built form;</li> <li>(c) screens areas of limited visual interest;</li> <li>(d) preserves the amenity of sensitive land uses; and</li> <li>(e) includes a range and variety of planting.</li> </ul>	<b>AO3.1</b> Development provides landscape treatments along side and rear boundaries in accordance with <b>Table 9.4.2.3B</b> .	✓	Can be conditioned to comply where relevant.
	<b>AO3.2</b> Shrubs and trees provided in landscape strips along side and rear boundaries: <ul style="list-style-type: none"> <li>(a) are planted at a maximum spacing of 1 metre;</li> <li>(b) will grow to a height of at least 2 metres;</li> <li>(c) will grow to form a screen of no less than 2 metres in height; and</li> <li>(d) are mulched to a minimum depth of 0.1 metres with organic mulch.</li> </ul>	✓	Can be conditioned to comply.

Performance outcomes	Acceptable outcomes	Complies	Comments
	<b>AO3.3</b> Any landscape strip provided along a side or rear boundary is designed in accordance with Planning Scheme Policy 6 - Landscaping and preferred plant species.	✓	Can be conditioned to comply.
<b>PO4</b> Car parking areas are improved with a variety of landscaping that: <ul style="list-style-type: none"> <li>(a) provides visual interest;</li> <li>(b) provides a source of shade for pedestrians;</li> <li>(c) assists to break up and soften elements; and</li> <li>(d) improves legibility.</li> </ul>	<b>AO4.1</b> Landscaping is provided in car parking areas which provides: <ul style="list-style-type: none"> <li>(a) a minimum of 1 shade tree for every 4 parking spaces, or part thereof, where the car parking area includes 12 or more spaces;</li> <li>(b) a minimum of 1 shade tree for every 6 parking spaces, or part thereof, otherwise; and</li> <li>(c) where involving a car parking area in excess of 500m<sup>2</sup>: <ul style="list-style-type: none"> <li>(i) shade structures are provided for 50% of parking spaces; and</li> <li>(ii) a minimum of 10% of the parking area as landscaping.</li> </ul> </li> </ul> <p>Note—Where a shade structure is provided over part of a car parking area, shade tree planting is not required in this area of the car parking area.</p>	n/a	Not applicable - No on-site car parking proposed.
	<b>AO4.2</b> Landscaping in car parking areas is designed in accordance with Planning Scheme Policy 6 - Landscaping and preferred plant species.	n/a	Not applicable - No on-site car parking proposed.
<b>PO5</b> Landscaping areas include a range and variety of planting that: <ul style="list-style-type: none"> <li>(a) is suitable for the intended purpose</li> </ul>	<b>AO5.1</b> Plant species are selected from the Plant Schedule in Planning Scheme Policy 6 - Landscaping and preferred plant species.	✓	Can be conditioned to comply.

Performance outcomes	Acceptable outcomes	Complies	Comments
and local conditions; (b) contributes to the natural character of the Shire; (c) includes native species; (d) includes locally endemic species, where practical; and (e) does not include invasive plants or weeds.	<b>AO5.2</b> A minimum of 25% of (new and existing) plants is provided as larger, advanced stock with a minimum plant height of 0.7 metres and mulched to a minimum depth of 0.1 metres with organic mulch.	✓	Can be conditioned to comply.
<b>PO6</b> Landscaping does not impact on the ongoing provision of infrastructure and services to the Shire.	<b>AO6.1</b> Tree planting is a minimum of (a) 2 metres from any underground water, sewer, gas, electricity or telecommunications infrastructure; and (b) 4 metres from any inspection chamber.	✓	Can be conditioned to comply.
	<b>AO6.2</b> Vegetation below or within 4 metres of overhead electricity lines and power poles has a maximum height of 3.5 metres at maturity.	✓	Can be conditioned to comply.
	<b>AO6.3</b> Vegetation adjoining an electricity substation boundary, at maturity, will have: (a) a height of less than 4 metres; and (b) no foliage within 3 metres of the substation boundary, unless the substation has a solid wall along any boundary.	n/a	Not applicable.
<b>For assessable development</b>			

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>P07</b> Landscaping areas are designed to: <ul style="list-style-type: none"> <li>(a) be easily maintained throughout the ongoing use of the site;</li> <li>(b) allow sufficient area and access to sunlight and water for plant growth;</li> <li>(c) not cause a nuisance to occupants of the site or members of the public; and</li> <li>(d) maintain or enhance the safety of pedestrians through the use of Crime Prevention Through Environmental Design principles.</li> </ul>	<b>A07</b> No acceptable outcome is provided.	✓	Can be conditioned to comply.

**Table 9.4.2.3B—Side and rear boundary landscape treatments**

Location or use	Landscape Strip Minimum Width	Screen Fencing Minimum Height	Extent of treatment
Where car parking, servicing or manoeuvring areas adjoin a side or rear boundary	1 metre	Not applicable	To the extent these areas adjoin the boundary
Where involving a use other than a dwelling house on a site with a common boundary with land in the Low density residential zone, the Medium density residential zone or the Rural residential zone:	1.5 metres	1.8 metres	Along the common boundary.
Development for an industrial activity which has a common boundary with land not within the Industry zone	2 metres	1.8 metres	Along the common boundary
Development involving (a) Tourist park not in the Rural zone (b) Sales office (c) Multiple dwelling (d) Residential care facility; or (e) Dual occupancy	Not applicable	1.8 metres	Along all side and rear boundaries and between dwellings for a Dual occupancy.
Development involving (a) Tourist park in the Rural zone (b) Service station (c) Car wash; or (d) Utility installation	2 metres	Not applicable	Along all side and rear boundaries
For: (a) waste storage; (b) equipment; (c) servicing areas; and (d) private open space and site facilities associated with Caretaker's accommodation.	Not applicable	1.8 metres	To prevent visibility

Note—Where more than one landscape treatment is applicable to a development in the above table, the development is to provide a landscape treatment that satisfies all applicable minimum specifications.

### 9.4.3 Parking and access code

#### 9.4.3.1 Application

This code applies to assessing development where it is identified in the assessment benchmarks for assessable development and requirements for accepted development column of an assessment table in Part 5 of the planning scheme.

#### 9.4.3.2 Purpose

- (1) The purpose of the Parking and access code is to ensure:
  - (a) parking areas are appropriately designed, constructed and maintained;
  - (b) the efficient functioning of the development and the local road network; and
  - (c) all development provides sufficient parking, loading/service and manoeuvring areas to meet the demand generated by the use.
- (2) The purpose of the code will be achieved through the following overall outcomes:
  - (a) Land uses have a sufficient number of parking and bicycle spaces designed in a manner to meet the requirements of the user;
  - (b) Parking spaces and associated manoeuvring areas are safe, functional and provide equitable access;
  - (c) Suitable access for all types of vehicles likely to utilise a parking area is provided in a way that does not compromise the safety and efficiency of the surrounding road network;
  - (d) Premises are adequately serviced to meet the reasonable requirements of the development; and
  - (e) End of trip facilities are provided by new major developments to facilitate alternative travel modes.

#### 9.4.3.3 Criteria for assessment

**Table 9.4.3.3A—Parking and access code – For accepted development subject to requirements and assessable development**

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>For accepted development subject to requirements and assessable development</b>			
<b>Car parking spaces</b>			

Performance outcomes	Acceptable outcomes	Complies	Comments
<p><b>PO1</b> Development provides sufficient car parking to accommodate the demand likely to be generated by the use, having regard to the:</p> <ul style="list-style-type: none"> <li>(a) nature of the use;</li> <li>(b) location of the site;</li> <li>(c) proximity of the use to public transport services;</li> <li>(d) availability of active transport infrastructure; and</li> <li>(e) accessibility of the use to all members of the community.</li> </ul>	<p><b>AO1</b> The number of car parking spaces provided for the use is in accordance with <b>Table 9.4.3.3B</b>.</p> <p>Note—Car parking spaces provided for persons with a disability are to be considered in determining compliance with AO1.</p>	✓	<p>The proposed development does not provide for any on-site car parking. The development is expected to generate very low levels of traffic and it is considered that existing on-street car parking along both Hyde Street, and Raleigh Street (31 parking spaces not including those immediately out the front of the pub) will provide sufficient parking to accommodate the low demand likely to be generated by the use.</p> <p>The proposed development is considered to comply with PO1.</p>
<b>Vehicle crossovers</b>			
<p><b>PO2</b> Vehicle crossovers are provided to::</p> <ul style="list-style-type: none"> <li>(a) ensure safe and efficient access between the road and premises;</li> <li>(b) minimize interference with the function and operation of roads; and</li> <li>(c) minimise pedestrian to vehicle conflict.</li> </ul>	<p><b>AO2.1</b> Vehicular access to/from Council roads is designed and constructed in accordance with the Standard drawings in Planning Scheme Policy 4 - FNQROC Regional Development Manual.</p>	✓	Can be conditioned to comply.

Performance outcomes	Acceptable outcomes	Complies	Comments
	<b>AO2.2</b> Development on a site with two or more road frontages provides vehicular access from: <ul style="list-style-type: none"> <li>(a) the primary frontage where involving Community activities or Sport and recreation activities, unless the primary road frontage is a State-controlled road; or</li> <li>(b) from the lowest order road in all other instances.</li> </ul>	✓	Complies.
	<b>AO2.3</b> Vehicular access for particular uses is provided in accordance with <b>Table 9.4.3.3E</b> .	✓	Can be conditioned to comply.
<b>PO3</b> Access, manoeuvring and car parking areas include appropriate pavement treatments having regard to: <ul style="list-style-type: none"> <li>(a) the intensity of anticipated vehicle movements;</li> <li>(b) the nature of the use that they service; and</li> <li>(c) the character of the surrounding locality.</li> </ul>	<b>AO3</b> Access, manoeuvring and car parking areas include pavements that are constructed in accordance with <b>Table 9.4.3.3C</b> .	✓	Can be conditioned to comply.
<b>For assessable development</b>			
<b>Parking area location and design</b>			
<b>PO4</b> Car parking areas are located and designed to: <ul style="list-style-type: none"> <li>(a) ensure safety and efficiency in operation; and</li> <li>(b) be consistent with the character of the surrounding locality.</li> </ul>	<b>AO4.1</b> Car parking spaces, access and circulation areas have dimensions in accordance with AS/NZS 2890.1 Off-street car parking.	n/a	Not applicable - no on-site parking proposed.

Performance outcomes	Acceptable outcomes	Complies	Comments
	<b>AO4.2</b> Disabled access and car parking spaces are located and designed in accordance with AS/NZS 2890.6 Parking facilities - Off-street parking for people with disabilities.	n/a	Not applicable - no on-site parking proposed.
	<b>AO4.3</b> The car parking area includes designated pedestrian routes that provide connections to building entrances.	n/a	Not applicable - no on-site parking proposed. An adequate pedestrian network exists within the road reserves to convey pedestrian from parking spaces to the site (sealed footpaths, pedestrian crossing).
	<b>AO4.4</b> Parking and any set down areas are: (a) wholly contained within the site; (b) visible from the street where involving Commercial activities, Community activities, Industrial activities or a use in the Recreation and open space zone; (c) are set back behind the main building line where involving a Dual occupancy, Multiple dwelling, Residential care facility or Retirement facility; and (d) provided at the side or rear of a building in all other instances.	n/a	Not applicable - no on-site parking proposed.
<b>Site access and manoeuvring</b>			

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>PO5</b> Access to, and manoeuvring within, the site is designed and located to: <ul style="list-style-type: none"> <li>(a) ensure the safety and efficiency of the external road network;</li> <li>(b) ensure the safety of pedestrians;</li> <li>(c) provide a functional and convenient layout; and</li> <li>(d) accommodate all vehicles intended to use the site.</li> </ul>	<b>A05.1</b> Access and manoeuvrability is in accordance with : <ul style="list-style-type: none"> <li>(a) AS28901 – Car Parking Facilities (Off Street Parking); and</li> <li>(b) AS2890.2 – Parking Facilities (Off-street Parking) Commercial Vehicle Facilities.</li> </ul> <p>Note—Proposal plans should include turning circles designed in accordance with AP34/95 (Austroads 1995) Design Vehicles and Turning Path Templates.</p>	✓	Can be conditioned to comply.
	<b>A05.2</b> Vehicular access has a minimum sight distance in accordance with Part 5 of AUSTROADS.	✓	Can be conditioned to comply. Access positioned dictated by DTMR.
	<b>A05.3</b> Vehicular access is located and designed so that all vehicles enter and exit the site in a forward gear.	✓	Will comply.
	<b>A05.4</b> Pedestrian and cyclist access to the site: <ul style="list-style-type: none"> <li>(a) is clearly defined;</li> <li>(b) easily identifiable; and</li> <li>(c) provides a connection between the site frontage and the entrance to buildings and end of trip facilities (where provided).</li> </ul>	✓	Will comply.

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>PO6</b> Development that involves an internal road network ensures that it's design: (a) ensure safety and efficiency in operation; (b) does not impact on the amenity of residential uses on the site and on adjoining sites, having regard to matters of: (i) hours of operation; (ii) noise (iii) light; and (iv) odour; (c) accommodates the nature and volume of vehicle movements anticipated to be generated by the use; (d) allows for convenient access to key on-site features by pedestrians, cyclists and motor vehicles; and (e) in the Rural zone, avoids environmental degradation.	<b>AO6.1</b> Internal roads for a Tourist park have a minimum width of: (a) 4 metres if one way; or (b) 6 metres if two way.	n/a	Not applicable.
	<b>AO6.2</b> For a Tourist park, internal road design avoids the use of cul-de-sacs in favour of circulating roads, where unavoidable, cul-de-sacs provide a full turning circle for vehicles towing caravans having: (a) a minimum approach and departure curve radius of 12 metres; and (b) a minimum turning circle radius of 8 metres.	n/a	Not applicable.
	<b>AO6.3</b> Internal roads are imperviously sealed and drained, apart from those for an Energy and infrastructure activity or Rural activity.	n/a	Not applicable.
	<b>AO6.4</b> Speed control devices are installed along all internal roads, apart from those for an Energy and infrastructure activity or Rural activity, in accordance with Complete Streets.	n/a	Not applicable.

Performance outcomes	Acceptable outcomes	Complies	Comments
	<b>AO6.5</b> Internal roads, apart from those for an Energy and infrastructure activity or Rural activity, are illuminated in accordance with AS 4282 (as amended) - Control of Obtrusive effects of outdoor lighting.	n/a	Not applicable.
	<b>AO6.6</b> Where involving an accommodation activity, internal roads facilitate unobstructed access to every dwelling, accommodation unit, accommodation site and building by emergency services vehicles.	n/a	Not applicable.
	<b>AO6.7</b> For an Energy and infrastructure activity or Rural activity, internal road gradients: (a) are no steeper than 1:5; or (b) are steeper than 1:5 and are sealed.	n/a	Not applicable.
<b>Servicing</b>			
<b>PO7</b> Development provides access, maneuvering and servicing areas on site that: (a) accommodate a service vehicle commensurate with the likely demand generated by the use; (b) do not impact on the safety or efficiency of internal car parking or maneuvering areas; (c) do not adversely impact on the safety or efficiency of the road network; (d) provide for all servicing	<b>AO7.1</b> All unloading, loading, service and waste disposal areas are located: (a) on the site; (b) to the side or rear of the building, behind the main building line; (c) not adjacent to a site boundary where the adjoining property is used for a sensitive use.	✓	Can be conditioned to comply where relevant.

Performance outcomes	Acceptable outcomes	Complies	Comments
(e) functions associated with the use; and are located and designed to minimise their impacts on adjoining sensitive land uses and streetscape quality.	<b>A07.2</b> Unloading, loading, service and waste disposal areas allow service vehicles to enter and exit the site in a forward gear.	✓	Can be conditioned to comply where relevant.
	<b>A07.3</b> Development provides a servicing area, site access and maneuvering areas to accommodate the applicable minimum servicing vehicle specified in <b>Table 9.4.3.3B</b> .	✓	Can be conditioned to comply where relevant.
<b>Maintenance</b>			
<b>PO8</b> Parking areas are used and maintained for their intended purpose.	<b>A08.1</b> Parking areas are kept and used exclusively for parking and are maintained in a suitable condition for parking and circulation of vehicles.	n/a	Not applicable.
	<b>A08.2</b> All parking areas will be compacted, sealed, drained, line marked and maintained until such time as the development ceases.	n/a	Not applicable.
<b>End of trip facilities</b>			
<b>PO9</b> Development within the Centre zone; Industry zone or Emerging community zone provides facilities for active transport users that: (a) meet the anticipated demand generated from the use; (b) comprise secure and convenient bicycle parking and storage; and (c) provide end of trip facilities for all active	<b>A09.1</b> The number of bicycle parking spaces provided for the use is in accordance with <b>Table 9.4.3.3D</b> .	n/a	Not applicable.

Performance outcomes	Acceptable outcomes	Complies	Comments
transport users.	<b>A09.2</b> End of trip facilities are provided in accordance with <b>Table 9.4.3.3D</b> .	<b>n/a</b>	Not applicable.
<b>If for Educational establishment or Child care centre where involving more than 100 vehicle movements per day or Renewable energy facility, Sport and recreation activities or Tourist park</b>			
<b>PO10</b> The level of traffic generated by the development on the surrounding local road network must not result in unacceptable impacts on adjacent land and local road users.	<b>A010</b> A traffic impact report is prepared by a suitably qualified person that identifies: (a) the expected traffic movements to be generated by the facility; (b) any associated impacts on the road network; and (c) any works that will be required to address the identified impacts.	<b>n/a</b>	Not applicable.
<b>If for Educational establishment or Child care centre where involving more than 100 vehicle movements per day or Renewable energy facility, Sport and recreation activities or Tourist park</b>			
<b>PO11</b> The level of traffic generated by the development on the surrounding local road network must not result in unacceptable impacts on adjacent land and local road users.	<b>A011</b> A traffic impact report is prepared by a suitably qualified person that identifies: (d) the expected traffic movements to be generated by the facility; (e) any associated impacts on the road network; and (f) any works that will be required to address the identified impacts.	<b>n/a</b>	Not applicable.

**Table 9.4.3.3B—Vehicle Parking and Service Vehicle Space Requirements**

Definition	Minimum number of Car parking spaces	Minimum Service Vehicle Space Provision
<b>Community use</b>	Minimum of 5 spaces per use or one space per 50m <sup>2</sup> or part thereof of GFA, whichever is greater.	One SRV space if greater than 500m <sup>2</sup> GFA.

## 9.4.5 Works, services and infrastructure code

### 9.4.5.1 Application

- (1) This code applies to assessing development where it is identified in the assessment benchmarks for assessable development and requirements for accepted development column of an assessment table in Part 5 of the planning scheme.

### 9.4.5.2 Purpose

- (1) The purpose of the Works, services and infrastructure code is to ensure that all development is appropriately serviced by physical infrastructure, public utilities and services and that work associated with development is carried out in a manner that does not adversely impact on the surrounding area.
- (2) The purpose of the code will be achieved through the following overall outcomes:
  - (a) Development provides an adequate, safe and reliable supply of potable, fire-fighting and general use water in accordance with relevant standards;
  - (b) Development provides for the treatment and disposal of wastewater and ensures there are no adverse impacts on water quality, public health, local amenity or ecological processes;
  - (c) Development provides for the disposal of stormwater and ensures that there are no adverse impacts on water quality or ecological processes;
  - (d) Development connects to the road network and any adjoining public transport, pedestrian and cycle networks while ensuring no adverse impacts on the safe, convenient and efficient operation of these networks;
  - (e) Development provides electricity and telecommunications services that meet its desired requirements;
  - (f) Development is connected to a nearby electricity network with adequate capacity without significant environment, social or amenity impact;
  - (g) Development does not affect the efficient functioning of public utility mains, services or installations;
  - (h) Infrastructure dedicated to Council is cost effective over its life cycle;
  - (i) Work associated with development does not cause adverse impacts on the surrounding area; and
  - (j) Development prevents the spread of weeds, seeds or other pests.

### 9.4.5.3 Criteria for assessment

**Table 9.4.5.3 - Works, services and infrastructure code – For accepted development subject to requirements and assessable development**

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>For accepted development subject to requirements and assessable development</b>			
<b>Water supply</b>			

Performance outcomes	Acceptable outcomes	Complies	Comments
<b>PO1</b> Each lot has an adequate volume and supply of water that: <ul style="list-style-type: none"> <li>(a) meets the needs of users;</li> <li>(b) is adequate for fire-fighting purposes;</li> <li>(c) ensures the health, safety and convenience of the community; and</li> <li>(d) minimises adverse impacts on the receiving environment.</li> </ul>	<b>AO1.1</b> Development is connected to a reticulated water supply system in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual other than where located: <ul style="list-style-type: none"> <li>(a) in the Conservation zone, Rural zone or Rural residential zone; and</li> <li>(b) outside a reticulated water supply service area.</li> </ul>	✓	Will be conditioned to comply.
	<b>AO1.2</b> Development, where located outside a reticulated water supply service area and in the Conservation zone, Rural zone or Rural residential zone is provided with: <ul style="list-style-type: none"> <li>(a) a bore or bores are provided in accordance with the Design Guidelines set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual; or</li> <li>(b) on-site water storage tank/s: <ul style="list-style-type: none"> <li>(i) with a minimum capacity of 90,000L;</li> <li>(ii) fitted with a 50mm ball valve with a camlock fitting; and</li> <li>(iii) which are installed and connected prior to the occupation or use of the development.</li> </ul> </li> </ul>	n/a	Not applicable.

<b>Wastewater disposal</b>			
<b>PO2</b> Each lot provides for the treatment and disposal of effluent and other waste water that: <ul style="list-style-type: none"> <li>(a) meets the needs of users;</li> <li>(b) is adequate for fire-fighting purposes;</li> <li>(c) ensures the health, safety and convenience of the community; and</li> <li>(d) minimises adverse impacts on the receiving environment.</li> </ul>	<b>AO2.1</b> Development is connected to a reticulated sewerage system in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual other than where located: <ul style="list-style-type: none"> <li>(a) in the Conservation zone, Rural zone or Rural residential zone; and</li> <li>(b) outside a reticulated sewerage service area.</li> </ul>	n/a	Not applicable.
	<b>AO2.2</b> An effluent disposal system is provided in accordance with ASNZ 1547 On-Site Domestic Wastewater Management (as amended) where development is located: <ul style="list-style-type: none"> <li>(a) in the Conservation zone, Rural zone or Rural residential zone; and</li> <li>(b) outside a reticulated sewerage service area.</li> </ul>	✓	Will be conditioned to comply for any future on-site wastewater disposal system.
<b>Stormwater infrastructure</b>			
<b>PO3</b> Stormwater infrastructure is designed and constructed to collect and convey the design storm event to a lawful point of discharge in a manner that mitigates impacts on life and property.	<b>AO3.1</b> Where located within a Priority infrastructure area or where stormwater infrastructure is available, development is connected to Council's stormwater network in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual.	✓	Can be conditioned to comply.

	<b>AO3.2</b> On-site drainage systems are constructed: <ul style="list-style-type: none"> <li>(a) to convey stormwater from the premises to a lawful point of discharge; and</li> <li>(b) in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual.</li> </ul>	✓	Will be conditioned to comply.
<b>Electricity supply</b>			
<b>PO4</b> Each lot is provided with an adequate supply of electricity	<b>AO4</b> The premises: <ul style="list-style-type: none"> <li>(a) is connected to the electricity supply network; or</li> <li>(b) has arranged a connection to the transmission grid; or</li> <li>(c) where not connected to the network, an independent energy system with sufficient capacity to service the development (at near average energy demands associated with the use) may be provided as an alternative to reticulated electricity where: <ul style="list-style-type: none"> <li>(i) it is approved by the relevant regulatory authority; and</li> <li>(ii) it can be demonstrated that no air or noise emissions; and</li> <li>(iii) it can be demonstrated that no adverse impact on visual amenity will occur.</li> </ul> </li> </ul>	✓	Can be conditioned to comply.
<b>Telecommunications infrastructure</b>			

<b>PO5</b> Each lot is provided with an adequate supply of telecommunication infrastructure	<b>A05</b> Development is provided with a connection to the national broadband network or telecommunication services.	✓	Can be conditioned to comply.
<b>Existing public utility services</b>			
<b>PO6</b> Development and associated works do not affect the efficient functioning of public utility mains, services or installations.	<b>A06</b> Public utility mains, services are relocated, altered or repaired in association with the works so that they continue to function and satisfy the relevant Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual.	✓	Will be conditioned to comply.
<b>Excavation or filling</b>			
<b>PO7</b> Excavation or filling must not have an adverse impact on the: (a) streetscape; (b) scenic amenity; (c) environmental values; (d) slope stability; (e) accessibility; or (f) privacy of adjoining premises.	<b>A07.1</b> Excavation or filling does not occur within 1.5 metres of any site boundary.	n/a	Not applicable.
	<b>A07.2</b> Excavation or filling at any point on a lot is to be no greater than 1.5 metres above or below natural ground level.	n/a	Not applicable.
	<b>A07.3</b> Earthworks batters: (a) are no greater than 1.5 metres in height; (b) are stepped with a minimum width 2 metre berm; (c) do not exceed a maximum of two batters and two berms (not greater than 3.6 metres in total height) on any one lot; (d) have a slope no greater than 1 in 4; and (e) are retained.	n/a	Not applicable.

	<p><b>A07.4</b> Soil used for filling or spoil from excavation is not stockpiled in locations that can be viewed from:</p> <ul style="list-style-type: none"> <li>(a) adjoining premises; or</li> <li>(b) a road frontage, for a period exceeding 1 month from the commencement of the filling or excavation.</li> </ul>	n/a	Not applicable.
	<p><b>A07.5</b> All batters and berms to be constructed in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual.</p>	n/a	Not applicable.
	<p><b>A07.6</b> Retaining walls have a maximum height of 1.5 metres and are designed and constructed in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development manual.</p>	n/a	Not applicable.
	<p><b>A07.7</b> Excavation or filling at any point on a lot is to include measures that protect trees at the foot or top of cut or fill batters by the use of appropriate retaining methods and sensitive earth removal or placement and in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development manual.</p>	✓ / x	
<b>For assessable development</b>			
<b>Transport network</b>			

<b>PO8</b> The development has access to a transport network of adequate standard to provide for the safe and efficient movement of vehicles, pedestrians and cyclists.	<b>A08.1</b> Vehicle access, crossovers, road geometry, pavement, utilities and landscaping to the frontage/s of the site are designed and constructed in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development manual.	✓	Can be conditioned to comply.
	<b>A08.2</b> Development provides footpath pavement treatments in accordance with Planning Scheme Policy 9 – Footpath Paving.	n/a	Not applicable.
<b>Public infrastructure</b>			
<b>PO9</b> The design, construction and provision of any infrastructure that is to be dedicated to Council is cost effective over its life cycle and incorporates provisions to minimise adverse impacts.	<b>A09</b> Development is in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual.	✓	Will be conditioned to comply.
<b>Stormwater quality</b>			

<p><b>PO10</b> Development has a non-worsening effect on the site and surrounding land and is designed to:</p> <ul style="list-style-type: none"> <li>(a) optimise the interception, retention and removal of waterborne pollutants, prior to the discharge to receiving waters;</li> <li>(b) protect the environmental values of waterbodies affected by the development, including upstream, on-site and downstream waterbodies;</li> <li>(c) achieve specified water quality objectives;</li> <li>(d) minimise flooding;</li> <li>(e) maximise the use of natural channel design principles;</li> <li>(f) maximise community benefit; and</li> <li>(g) minimise risk to public safety.</li> </ul>	<p><b>AO10.1</b> The following reporting is prepared for all Material change of use or Reconfiguring a lot proposals:</p> <ul style="list-style-type: none"> <li>(a) a Stormwater Management Plan and Report that meets or exceeds the standards of design and construction set out in the Queensland Urban Drainage Manual (QUDM) and the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual; and</li> <li>(b) an Erosion and Sediment Control Plan that meets or exceeds the Soil Erosion and Sedimentation Control Guidelines (Institute of Engineers Australia), including: <ul style="list-style-type: none"> <li>(i) drainage control;</li> <li>(ii) erosion control;</li> <li>(iii) sediment control; and</li> <li>(iv) water quality outcomes.</li> </ul> </li> </ul>	<p><b>n/a</b></p>	<p>Not applicable (considering the scale of development proposed).</p>
--	--	-------------------	--

	<p><b>AO10.2</b></p> <p>For development on land greater than 2,500m<sup>2</sup> or that result in more than 5 lots or more than 5 dwellings or accommodation units, a Stormwater Quality Management Plan and Report prepared and certified by a suitably qualified design engineer (RPEQ) is prepared that demonstrates that the development:</p> <ul style="list-style-type: none"> <li>(a) meets or exceeds the standards of design and construction set out in the Urban Stormwater Quality Planning Guideline and the Queensland Water Quality Guideline;</li> <li>(b) is consistent with any local area stormwater water management planning;</li> <li>(c) accounts for development type, construction phase, local climatic conditions and design objectives; and</li> <li>(d) provides for stormwater quality treatment measures reflecting land use constraints, such as soil type, landscape features (including landform), nutrient hazardous areas, acid sulfate soil and rainfall erosivity.</li> </ul>	n/a	Not applicable (considering the scale of development proposed).
--	---	-----	---

<p><b>PO11</b> Storage areas for stormwater detention and retention:</p> <ul style="list-style-type: none"> <li>(a) protect or enhance the environmental values of receiving waters;</li> <li>(b) achieve specified water quality objectives;</li> <li>(c) where possible, provide for recreational use;</li> <li>(d) maximise community benefit; and</li> <li>(e) minimise risk to public safety.</li> </ul>	<p><b>AO11</b> No acceptable outcome is provided.</p>	<p><b>n/a</b></p>	<p>Not applicable (considering the scale of development proposed).</p>
<p><b>Excavation or filling</b></p>			
<p><b>PO12</b> Traffic generated by filling or excavation does not impact on the amenity of the surrounding area.</p>	<p><b>AO12.1</b> Haul routes used for transportation of fill to or from the site only use major roads and avoid residential areas.</p>	<p><b>n/a</b></p>	<p>Not applicable.</p>
	<p><b>AO12.2</b> Transportation of fill to or from the site does not occur:</p> <ul style="list-style-type: none"> <li>(a) within peak traffic times; and</li> <li>(b) before 7am or after 6pm Monday to Friday;</li> <li>(c) before 7am or after 1pm Saturdays; and</li> <li>(d) on Sundays or Public Holidays.</li> </ul>	<p><b>n/a</b></p>	<p>Not applicable.</p>

<b>PO13</b> Air pollutants, dust and sediment particles from excavation or filling, do not cause significant environmental harm or nuisance impacts.	<b>AO13.1</b> Dust emissions do not extend beyond the boundary of the site.	n/a	Not applicable.
	<b>AO13.2</b> No other air pollutants, including odours, are detectable at the boundary of the site.	n/a	Not applicable.
	<b>AO13.3</b> A management plan for control of dust and air pollutants is prepared and implemented.	n/a	Not applicable.
<b>PO14</b> Access to the premises (including driveways and paths) does not have an adverse impact on: (a) safety; (b) drainage; (c) visual amenity; and (d) privacy of adjoining premises.	<b>AO14</b> Access to the premises (including all works associated with the access): (a) must follow as close as possible to the existing contours; (b) be contained within the premises and not the road reserve, and (c) are designed and constructed in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development manual.	n/a	Not applicable.
<b>Weed and pest management</b>			
<b>PO15</b> Development prevents the spread of weeds, seeds or other pests into clean areas or away from infested areas.	<b>AO15</b> No acceptable outcome is provided.	n/a	Not applicable.
<b>Contaminated land</b>			
<b>PO16</b> Development is located and designed to ensure that users and nearby sensitive land uses are not exposed to unacceptable levels of contaminants	<b>AO16</b> Development is located where: (a) soils are not contaminated by pollutants which represent a health or safety risk to users; or (b) contaminated soils are remediated prior to plan sealing, operational works permit, or issuing of building works permit.	n/a	Not applicable.

Fire services in developments accessed by common private title			
<b>PO17</b> Fire hydrants are located in positions that will enable fire services to access water safely, effectively and efficiently.	<b>AO17.1</b> Fire hydrants are located in accessways or private roads held in common private title at a maximum spacing of: (a) 120 metres for residential development; and (b) 90 metres for any other development.	n/a	Not applicable.
	<b>AO17.2</b> Fire hydrants are located at all intersections of accessways or private roads held in common private title.	n/a	Not applicable.