Assessment of application against relevant Development Codes

APPLICATION DETAILS

APPLICATION		PREI	MISES
FILE NO:	MCU/18/0006	ADDRESS:	77 & 112 Barnwell Road, Kuranda
APPLICANT:	Reever and Ocean Pty Ltd	RPD:	Lot 16 on N157227, Lot 17, 18, 19 and 22 on SP296830
LODGED BY:	Cardno	AREA:	Lot 16 - 57.61 ha Lot 17 - 63.12 ha Lot 18 - 69.81 ha Lot 19 - 43.49 ha Lot 22 - 107.3 ha
DATE LODGED:	15 March 2018	OWNER:	Lot 16 - A & A Easton & B Martin Lots 17, 18, 19 & 22 - Reever and Ocean Pty Ltd
TYPE OF APPROVAL:	Development Permit	'	
PROPOSED DEVELOPMENT:	Material Change of U	Jse - Tourist A	ttraction
PLANNING SCHEME:	Mareeba Shire Coun	icil Planning So	cheme 2016
ZONE:	Rural zone		
LEVEL OF ASSESSMENT:	Code Assessment		
SUBMISSIONS:	n/a		

Relevant Development Codes

The following Development Codes are considered to be applicable to the assessment of the application:

- 6.2.9 Rural zone code
- 8.2.2 Airport environs overlay code
- 8.2.4 Environmental significance overlay code
- 9.4.2 Landscaping code
- 9.4.5 Works, services and infrastructure code

6.2.9 Rural zone code

6.2.9.1 Application

- (1) This code applies to assessing development where:
 - (a) located in the Rural zone; and
 - (b) it is identified in the assessment benchmarks for assessable development and requirements for accepted development column of an assessment table in Part 5 of the planning scheme.

6.2.9.2 Purpose

- (1) The purpose of the Rural zone code is to:
 - (a) provide for rural uses including cropping, intensive horticulture, intensive animal industries, animal husbandry, animal keeping and other primary production activities;
 - (b) provide opportunities for non-rural uses that are compatible with agriculture, the environmental features, and landscape character of the rural area where the uses do not compromise the long-term use of the land for rural purposes;
 - (c) protect or manage significant natural resources and processes to maintain the capacity for primary production.
- (2) Mareeba Shire Council's purpose of the Rural zone code is to recognise the importance of primary production to the economy of the region and to maintain and strengthen the range of primary industries which contribute to the rural economy.

The purpose of the Rural zone code is to:

- (a) recognise the diversity of rural uses that exists throughout the region;
- (b) protect the rural character of the region;
- (c) provide facilities for visitors and tourists that are accessible and offer a unique experience;
- (d) protect the infrastructure of the Mareeba-Dimbulah Irrigation Scheme Area from development which may compromise long term use for primary production;
- (e) maintain distinct boundaries between the rural areas and the villages, towns and urban areas of the region;
- (f) provide for a range of uses, compatible and associated with rural or ecological values including recreational pursuits and tourist activities;
- (g) prevent adverse impacts of development on ecological values;
- (h) preserve land in large holdings; and
- (i) facilitate the protection of strategic corridors across the landscape which link remnant areas of intact habitat and transport corridors.
- (3) The purpose of the Rural zone code will be achieved through the following overall outcomes:
 - (a) Areas for use for primary production are conserved and fragmentation below economically viable lot sizes is avoided;
 - (b) The establishment of a wide range of rural pursuits is facilitated, including cropping, intensive horticulture, forestry, intensive animal industries, animal husbandry and animal keeping and other compatible primary production uses;
 - (c) The establishment of extractive industries, mining and associated activities and alternative forms of energy generation is appropriate where environmental impacts and land use conflicts are minimised;
 - (d) Uses that require isolation from urban areas as a consequence of their impacts such as noise or odour may be appropriate where land use conflicts are minimised;

- (e) Development is reflective of and responsive to the environmental constraints of the land:
- (f) Residential and other development is appropriate only where directly associated with the rural nature of the zone;
- (g) Low-impact tourism and recreation activities do not compromise the long-term use of the land for rural purposes;
- (h) The viability of both existing and future rural uses and activities is protected from the intrusion of incompatible uses;
- (i) Visual impacts of clearing, building, materials, access ways and other aspects of development are minimised or appropriately managed;
- (j) Adverse impacts of development both on-site and from adjoining areas are avoided and any impacts are minimised through location, design, operation and management; and
- (k) Natural features such as creeks, gullies, waterways, wetlands and bushland are retained, managed, enhanced and separated from adjacent development.

6.2.9.3 Criteria for assessment

Table 6.2.9.3—Rural zone code - For accepted development subject to requirements and assessable development

Performance outcomes	Acceptable outcomes	Complies	Comments	
For accepted development subject to requirements and assessable development				
Height				

Performance outcomes	Acceptable outcomes	Complies	Comments
PO1 Building height takes into consideration and respects the following: (a) the height of existing buildings on adjoining premises; (b) the development potential, with respect to height, on adjoining premises; (c) the height of buildings in the vicinity of the site; (d) access to sunlight and daylight for the site and adjoining sites; (e) privacy and overlooking; and (f) site area and street frontage length.	AO1.1 Development, other than buildings used for rural activities, has a maximum building height of: (a) 8.5 metres; and (b) 2 storeys above ground level.		The development complies. The buildings and structures proposed as part of the development are 1-2 storeys and 8.5 metres or less in height, apart from the horse pen roof, which has a maximum height of 8.772 metres. The applicant has demonstrated the horse pen's compliance with PO1: "The maximum height of the structure relates only to a small area of the roof near its peak. The majority of the structure, due to the sloped roof design is below 8.5 metres in height and therefore compliant with AO1.1. The height of 8.772 metres is consistent and compatible with other buildings and structures

Performance outcomes	Acceptable outcomes	Complies	Comments
			on the site which are 8.5 metres or less in height.
			The exceedance in height of 0.272 metres is considered minimal.
			The height of the horse pen roof is consistent with similar structures found on rural properties throughout the shire, as demonstrated through consideration of AO1.2, which permits buildings and structures used for rural activities to extend up to 10 metres in height.
			The horse pen roof is not highly visible from areas external to the site and is grouped near other structures of a similar height.
			The proposed horse pen roof is well separated from site boundaries and is not located proximate to any buildings or

Perf	ormance outcomes	Acceptable outcomes	Complies	Comments
				structures on adjoining land. The site comprises an expansive rural land holding and the overall scale of the horse pen roof is consistent with the scale and nature of the site."
		AO1.2 Buildings and structures associated with a rural activity including machinery, equipment, packing or storage buildings do not exceed 10 metres in height.	•	The development complies.
	ng, where not involving	•		
PO2 Deve		AO2.1 Buildings and structures include a minimum setback of: (a) 40 metres from a frontage to a Statecontrolled road; and (b) 10 metres from a boundary to an adjoining lot.	t Code apply. ✓	Complies.
(c) (d) (e) (f)	privacy and overlooking; air circulation and access to natural breezes; appearance of building bulk; and relationship with road	AO2.2 Buildings and structures, where for a Roadside stall, include a minimum setback of 0 metres from a frontage to a road that is not a State-controlled road.	n/a	Not applicable.

Performance outcomes	Acceptable outcomes	Complies	Comments			
corridors.	AO2.3 Buildings and structures, except where a Roadside stall, include a minimum setback of: (a) 10 metres from a frontage to a sealed road that is not a State-controlled road; and (b) 100 metres from a frontage to any other road that is not a State-controlled road;	•	Complies.			
Accommodation density						
PO3 The density of Accommodation activities: (a) respects the nature	AO3.1 Residential density does not exceed one dwelling house per lot.	•	Complies.			
and density of surrounding land use; (b) is complementary and subordinate to the rural and natural landscape values of the area; and (c) is commensurate to the scale and frontage of the site.	AO3.2 Residential density does not exceed two dwellings per lot and development is for: (a) a secondary dwelling; or (b) Caretaker's accommodation and includes building work or minor building work with a maximum gross floor area of 100m²; or (c) Rural worker's accommodation.		Complies.			
For assessable developme	For assessable development					
Site cover						

Performance outcomes	Acceptable outcomes	Complies	Comments
PO4 Buildings and structures occupy the site in a manner that: (a) makes efficient use of land; (b) is consistent with the bulk and scale of buildings in the surrounding area; and (c) appropriately balances built and natural features.	AO4 No acceptable outcome is provided.	•	The proposed development will involve the use of small scale structures and will retain the overall rural character of the subject site.
PO5 Development complements and integrates with the established built character of the Rural zone, having regard to: (a) roof form and pitch; (b) eaves and awnings; (c) building materials, colours and textures; and (d) window and door size and location.	AO5 No acceptable outcome is provided.	•	The proposed development will involve the use of small scale structures and will retain the overall rural character of the subject site.
Amenity			

Performance outcomes	Acceptable outcomes	Complies	Comments
PO6 Development must not detract from the amenity of the local area, having regard to: (a) noise; (b) hours of operation; (c) traffic; (d) advertising devices; (e) visual amenity; (f) privacy; (g) lighting; (h) odour; and (i) emissions.	A06 No acceptable outcome is provided.		Complies. The applicant's response satisfies PO6. The applicant states that "The proposed development involves a low scale Tourist Attraction use. The use is located internal to the site, with all tourist activities being well separated from adjoining properties. The proposed development provides tourist experiences associated with the existing rural use of the site and will therefore not alter the rural character and amenity of the site and surrounding area. Bus transport will be primarily utilised to minimise vehicle movements in the local area. Tourists will attend the site between the hours of 7:00am and 7:00pm."

Performance outcomes	Acceptable outcomes	Complies	Comments
PO7 Development must take into account and seek to ameliorate any existing negative environmental impacts, having regard to: (a) noise; (b) hours of operation; (c) traffic; (d) advertising devices; (e) visual amenity; (f) privacy; (g) lighting; (h) odour; and (i) emissions.	AO7 No acceptable outcome is provided.		Complies. The applicant's response satisfies PO7. The applicant states that "The proposed development is located in an established rural area. The proposed development and the existing uses of the site are compatible with the amenity and character of the surrounding area."

8.2.2 Airport environs overlay code

8.2.2.1 Application

- (1) This code applies to assessing development where:
 - (a) land the subject of development is affected by a constraint category identified on the **Airport** environs overlay maps (OM-002a-f); and
 - (b) it is identified in the assessment benchmarks for assessable development and requirements for accepted development column of an assessment table in Part 5 of the planning scheme.

Note—Strategic airports and aviation facilities are appropriately reflected in Overlay Map 2 and is required to be mapped by State Government in response to Infrastructure State Interests.

8.2.2.2 Purpose

- (1) The purpose of the Airport environs overlay code is to protect the current and ongoing operations of established airports, aerodromes and aviation infrastructure in Mareeba Shire.
- (2) The purpose of the code will be achieved through the following overall outcomes:
 - (a) The ongoing operation of Mareeba Airport and its associated infrastructure are protected from incompatible development;
 - (b) Aerodromes in Chillagoe and Dimbulah are maintained to support recreation, mining and rural uses;
 - (c) Operational airspace is protected:
 - (d) Threats to aviation safety such as bird and bat strike and distraction or blinding of pilots are avoided or minimised;
 - (e) State significant aviation facilities associated with the Mareeba Airport are protected from encroachment by sensitive land uses; and
 - (f) Development in the vicinity of airports, aerodromes and aviation infrastructure does not compromise public safety.

8.2.2.3 Criteria for assessment

Table 8.2.2.3 - Airport environs overlay code - For accepted development subject to requirements and assessable development

Performance outcomes	Acceptable outcomes	Complies	Comments			
For accepted development s	For accepted development subject to requirements and assessable development					
Protection of operational air	space					
PO1 Development does not interfere with movement of aircraft or the safe operation of an airport or aerodrome where within the: (a) Airport environs: OLS area of Mareeba Airport identified on Airport environs overlay map (OM-002c); or (b) Airport environs: OLS area of Cairns Airport identified on Airport identified on Airport	AO1.1 Development does not exceed the height of the Obstacle Limitation Surface (OLS) where located within the Airport environs: OLS area of: (a) Mareeba Airport identified on Airport environs overlay map (OM-002c); or (b) Cairns Airport identified on Airport environs overlay map (OM-002c.1).	•	The proposed development will not exceed the height of the Cairns Airport OLS.			
environs overlay map (OM-002c.1); or (c) 'Airport environs: Airport buffer - 1 kilometre' of an aerodrome identified on Airport environs overlay map (OM-	AO1.2 Development has a maximum height of 10 metres where within the 'Airport environs: Airport buffer - 1 kilometre' of an aerodrome identified on Airport environs overlay map (OM-002f).	n/a	Not applicable. The subject land is not within a 1 kilometre buffer.			
(d) 'Airport environs: Airport buffer - 3 kilometres' of an aerodrome identified on Airport environs overlay map (OM- 002f).	AO1.3 Development has a maximum height of 15 metres where within the 'Airport environs: Airport buffer - 3 kilometres' of an aerodrome identified on Airport environs overlay map (OM-002f).	n/a	Not applicable. The subject land is not within a 3 kilometre buffer.			
Lighting						

Performance outcomes	Acceptable outcomes	Complies	Comments	
PO2 Development does not include lighting that: (a) has the potential to impact on the efficient and safe operation of Mareeba Airport or an aerodrome; or (b) could distract or confuse pilots.	AO2 Development within the 'Airport environs: Distance from airport - 6 kilometres' area for Mareeba Airport identified on Airport environs overlay map (OM- 002b) or the 'Airport environs: Airport buffer - 3 kilometres' of an aerodrome identified on Airport environs overlay map (OM-002f) does not: (a) involve external lighting, including street lighting, that creates straight parallel lines of lighting that are more than 500 metres long; and (b) does not contain reflective cladding upwards shining lights, flashing lights or sodium lights.	n/a	Not applicable. The subject land is not within the nominated buffer/s.	
Noise exposure				
PO3 Development not directly associated with Mareeba Airport is protected from aircraft noise levels that may cause harm or undue interference.	AO3 Sensitive land uses are acoustically insulated to at least the minimum standards specified by AS2021 Acoustics - Aircraft Noise Intrusion - Building Siting and Construction where located within the 'Airport environs: 20-25 ANEF' area identified on Airport environs overlay map (OM-002d).	n/a	Not applicable.	
Public safety				
PO4 Development does not compromise public safety or risk to property.	AO4 Development is not located within the 'Airport environs: Mareeba Airport public safety area' identified on Airport environs overlay map (OM-002e).	n/a	Not applicable.	
State significant aviation facilities associated with Mareeba Airport				

Perf	ormance outcomes	Acceptable outcomes	Complies	Comments
impa sign	elopment does not air the function of state ificant aviation facilities reating: physical obstructions; or electrical or electromagnetic interference;	AO5.1 Development within 'Airport environs: Zone B (600 metre buffer)' for the 'Saddle Mountain VHF' facility identified on Airport environs overlay map (OM-002a.1) does not exceed a height of 640 metres AHD.	n/a	Not applicable.
(c)	or deflection of signals.	AO5.2 Development within 'Airport environs: Zone B (4,000 metre buffer)' for the 'Hahn Tableland Radar (RSR)' facility identified on Airport environs overlay map (OM-002a) does not exceed a height of 950 metres AHD, unless associated with Hann Tableland Radar facility.	n/a	Not applicable.
		AO5.3 Building work does not occur within 'Airport environs: Zone A (200 metre buffer)' of the 'Biboohra CVOR' facility identified on Airport environs overlay map (OM-002a) unless associated with the Biboohra CVOR facility.	n/a	Not applicable.

Performance outcomes	Acceptable outcomes	Complies	Comments
	AO5.4 Development within 'Airport environs: Zone B (1,500 metre buffer)' of the 'Biboohra CVOR' facility identified on Airport environs overlay map (OM-002a), but outside 'Zone A (200 metre buffer)' identified on Airport environs overlay map (OM-002a), does not include: (a) the creation of a permanent or temporary physical line of sight obstruction above 13 metres in height; or (b) overhead power lines exceeding 5 metres in height; or (c) metallic structures exceeding 7.5 metres in height; or (d) trees and open lattice towers exceeding 10 metres in height; or (e) wooden structures exceeding 13 metres in height.	n/a	Not applicable.
For assessable developmer	10		
Mareeba Airport			
Protection of operational air	<u> </u>		
PO6 Development within the vicinity of Mareeba Airport or an aerodrome does not interfere with the: (a) movement of aircraft; or (b) safe operation of the airport or facility.	AO6.1 Development involving sporting and recreational aviation activities such as parachuting, hot air ballooning or hang gliding, does not occur within the Airport environs: OLS area of: (a) Mareeba Airport identified on Airport environs overlay map (OM-002c); or (b) Cairns Airport identified on Airport environs overlay map (OM-002c.1).		The proposed development does not include aviation related activities.

Performance outcomes	Acceptable outcomes	Complies	Comments
	AO6.2 Development involving temporary or permanent aviation activities does not occur within the 'Airport environs: Airport buffer - 3 kilometres' of an aerodrome identified on Airport environs overlay map (OM-002f).	•	Complies. The proposed development does not include aviation related activities.
PO7 Development does not affect air turbulence, visibility or engine operation in the operational airspace of Mareeba Airport or regional aerodromes.	AO7 Development does not result in the emission of a gaseous plume, at a velocity exceeding 4.3 metres per second, or smoke, dust, ash or steam within: (a) the Airport environs: OLS area of Mareeba Airport identified on Airport environs overlay map (OM-002c); or (b) the Airport environs: OLS area of Cairns Airport identified on Airport environs overlay map (OM-002c.1); or (c) the 'Airport environs: Airport buffer - 1 kilometre' of a regional aerodrome identified on Airport environs overlay map (OM-002f).		Complies. The proposed development will not result in the emission of a gaseous plume, at a velocity exceeding 4.3 metres per second, or smoke, dust, ash or steam.

Performance outcomes	Acceptable outcomes	Complies	Comments		
Managing bird and bat strike	Managing bird and bat strike hazard to aircraft				
PO8 Development in the environs of Mareeba Airport or an aerodrome does not contribute to the potentially serious hazard from wildlife (bird or bat) strike.	AO8.1 Development within the 'Airport environs: Distance from airport - 8 kilometres' Bird and bat strike zone of Mareeba Airport identified on Airport environs overlay map (OM-002b) or the 'Airport environs: Airport buffer - 3 kilometres' of an aerodrome identified on Airport environs overlay map (OM-002f) provides that potential food and waste sources are covered and collected so that they are not accessible to wildlife.	n/a	Not applicable.		
	AO8.2 Development within the 'Airport environs: Distance from airport - 3 kilometres' Bird and bat strike zone of Mareeba Airport identified on Airport environs overlay map (OM-002b) or the 'Airport environs: Airport buffer - 1 kilometre' of an aerodrome identified on Airport environs overlay map (OM-002f) does not include: (a) food processing; or (b) abattoir; or (c) intensive horticulture; or (d) intensive animal husbandry; or (e) garden centre; or (f) aquaculture.	n/a	Not applicable.		

Performance outcomes	Acceptable outcomes	Complies	Comments
	AO8.3 Putrescible waste disposal sites do not occur within the 'Airport environs: Distance from airport - 13 kilometres' Bird and bat strike zone of: (a) Mareeba Airport identified on Airport environs overlay map (OM-002b); or (b) Cairns Airport identified on Airport environs overlay map (OM-002b.1).	n/a	Not applicable.

8.2.4 Environmental significance overlay code

8.2.4.1 Application

- (1) This code applies to assessing development where:
 - (a) land the subject of development is affected by a constraint category identified on the **Environmental significance overlay maps (OM-004a-z)**; and
 - (b) it is identified in the assessment benchmarks for assessable development and requirements for accepted development column of an assessment table in Part 5 of the planning scheme.

Note—Biodiversity and Water quality are appropriately reflected in Overlay Map 4 and is required to be mapped by State Government in response to Environment and Heritage State Interests.

8.2.4.2 Purpose

(1) The purpose of the Environmental significance overlay code is to identify and protect matters of environmental significance, which include matters of state environmental significance (MSES) as defined under the state planning policy.

The Environmental significance overlay code ensures that:

- (a) waterways and high ecological significance wetlands are protected and enhanced to maintain ecosystem services and hydrological processes and provide aquatic habitat for flora and fauna; and
- (b) the environmental values of regulated vegetation, wildlife habitat, protected areas and legally secured offset areas are protected and managed.
- (2) The purpose of the code will be achieved through the following overall outcomes:
 - (a) the biodiversity values, ecosystem services and climate change resilience of areas of environmental significance are protected, managed, enhanced and rehabilitated;
 - (b) the biodiversity values of protected areas and legally secured offset areas are protected from development unless overriding community need is demonstrated;
 - (c) development is located, designed and managed to minimise the edge effects of development on areas of regulated vegetation and wildlife habitat;
 - (d) areas of regulated vegetation and wildlife habitat are managed to minimise biodiversity losses:
 - development maintains, protects and enhances a regional network of vegetated corridors that assist in wildlife movement and contribute to the maintenance of habitat and biological diversity;
 - (f) development is appropriately setback from waterways and high ecological significance wetlands to minimise direct and indirect impacts on water quality and biodiversity; and
 - (g) riparian vegetation and vegetation associated with high ecological significance wetlands is protected and enhanced to improve water quality and natural ecosystem function.

8.2.4.3 Criteria for assessment

Table 8.2.4.3A - Environmental significance overlay code - For accepted development

subject to requirements and assessable development

	ormance outcomes	Acceptable outcomes	Complies	Comments	
For	For accepted development subject to requirements and assessable development				
Reg	ulated vegetation				
PO1 Veg map vege Env Sigi	etation clearing in areas ped as 'Regulated etation' identified on the ironmental nificance Overlay Maps 1-004a-o) is avoided ss: it is demonstrated that the area does not support regulated vegetation as mapped; the loss or reduction in regulated vegetation is for community infrastructure and associated access facilities that cannot be avoided; wildlife interconnectivity is maintained or enhanced at a local and regional scale; and the loss or reduction in regulated vegetation is minimised and any residual impacts are offset.	AO1.1 No clearing of native vegetation is undertaken within areas of 'Regulated vegetation' identified on the Environmental Significance Overlay Maps (OM-004a-o).		The proposed development does not involve the clearing of regulated vegetation.	
accor	ssment Report is prepared in dance with Planning Scheme 2 – Ecological Assessment rts.				
to ar vege Envi	elopment on sites adjacent eas of 'Regulated station' identified on the ronmental Significance rlay Maps (OM-004a-o) ects the environmental ficance of regulated station and: does not interrupt, interfere, alter or otherwise impact on underlying natural	AO2 Development (excluding roads, earthworks, drainage infrastructure and underground infrastructure) is not located within 20 metres of 'Regulated vegetation' areas identified on the Environmental Significance Overlay Maps (OM-004a-o).	•	The development complies. Setbacks in excess of 20 metres will be achieved.	

Performance outcomes	Acceptable outcomes	Complies	Comments
ecosystem processes such as water quality, hydrology, geomorphology and biophysical processes; (b) does not negatively impact the movement of wildlife at a local or regional scale; and (c) avoids noise, light, vibration or other edge affects, including weed and pest incursion on identified environmental values. Note—A supporting Ecological Assessment Report is prepared in accordance with Planning Scheme			
Policy 2 – Ecological Assessment Reports.			
Regulated vegetation interse	ecting a watercourse		
PO3 Vegetation clearing in areas mapped as 'Regulated vegetation intersecting a watercourse', identified as 'Waterway' and 'Waterway buffer' on the Environmental Significance - Waterway Overlay Maps (OM-004p-z) is avoided unless wildlife interconnectivity between habitats is maintained or enhanced at a local and regional scale, to the extent that migration or normal movement of significant species between habitats or	Where within a 'Waterway buffer' on Environmental Significance - Waterway Overlay Maps (OM-004p-z) AO3.1 A minimum setback in accordance with Table 8.2.4.3B is provided between development and the top of the high bank of a 'Waterway' identified on the Environmental Significance - Waterway Overlay Maps (OM-004p-z).	•	The proposed development complies. The development will exceed the minimum setbacks specified in Table 8.2.4.3B.
normal gene flow between populations is not inhibited. Note—A supporting Ecological Assessment Report is prepared in accordance with Planning Scheme Policy 2 – Ecological Assessment Reports. Waterways and wetlands	Where within a 'Waterway buffer' on Environmental Significance - Waterway Overlay Maps (OM-004p-z) AO3.2 No clearing of native vegetation is undertaken within the minimum setback identified at AO3.1.	•	The proposed development does not involve the clearing of vegetation.

Perforn	nance outcomes	Acceptable outcomes	Complies	Comments
wetland Enviror Overlay and 'Wa Enviror Waterw 004p-z) (a) m s b w a (b) m	'High ecological significance wetlands' identified on the Environmental Significance Overlay Maps (OM-004a-o) and 'Waterways' on Environmental Significance - Waterway Overlay Maps (OM-004p-z) and are protected by: (a) maintaining adequate separation distances between waterways/wetlands and development;	Where within a 'Waterway buffer' on Environmental Significance - Waterway Overlay Maps (OM-004p-z) AO4.1 A minimum setback in accordance with Table 8.2.4.3B is provided between development and the top of the high bank of a 'Waterway' identified on the Environmental Significance - Waterway Overlay Maps (OM-004p-z).		The proposed development complies. The development will exceed the minimum setbacks specified in Table 8.2.4.3B.
(c) m (d) m (d) m (d) m	nhancing aquatic and errestrial habitat including vegetated orridors to allow for ative fauna rerrestrial and quatic) movement; inaintaining waterway ank stability by ininimising bank rosion and slumping; inaintaining water uality by providing uffers to allow ltering of sediments,	Where within a 'High ecological significance wetland buffer' on Environmental Significance Overlay Maps (OM-004a-o) AO4.2 A minimum buffer of 200 metres is provided between development and the edge of a 'High ecological significance wetland' identified on the Environmental Significance Overlay Maps (OM-004a-o).	n/a	The subject site is not in proximity to a high ecological significance wetland buffer.
n p (e) re ir ri a v w w Note—A Assessme accordance	utrients and other ollutants; and etaining and mproving existing parian vegetation nd existing egetation associated with a wetland. supporting Ecological ent Report is prepared in ce with Planning Scheme – Ecological Assessment	Where within a 'Waterway buffer' on Environmental Significance - Waterway Overlay Maps (OM-004p-z) or 'High ecological significance wetland buffer' on Environmental Significance Overlay Maps (OM-004a-o) AO4.3 No stormwater is discharged to a 'Waterway' on Environmental Significance - Waterway Overlay Maps (OM-004p-z) or 'High ecological significance wetland' identified on the Environmental Significance Overlay Maps (OM-004a-o).	•	The proposed development will not meanifully alter the existing stormwater characteristics of the subject site.

Performance outcomes	Acceptable outcomes	Complies	Comments
T enormance outcomes	Note— An alternative outcome is required to demonstrate that the ecological impacts of stormwater discharge to a 'Waterway' or 'High ecological significance wetland' are mitigated in accordance with PO3 through appropriate stormwater management / treatment (where possible).	отприез	Comments
	Where within a 'Waterway buffer' on Environmental Significance - Waterway Overlay Maps (OM-004p-z) or 'High ecological significance wetland buffer' on Environmental Significance Overlay Maps (OM-004a-o) AO4.4 No wastewater is discharged to a 'Waterway' on Environmental Significance - Waterway Overlay Maps (OM-004p-z) or 'High ecological significance wetland' identified on the Environmental Significance Overlay Map (OM-004a-z). Note— A alternative outcome is required to demonstrate that the ecological impacts of wastewater discharge to a 'Waterway' or 'High ecological significance wetland' are mitigated in accordance with PO3 through appropriate		The development complies.
	wastewater management / treatment (where possible).		
For assessable developmen	Ι τ		
Wildlife Habitat PO5	AO5	~	Complies. The
Development within a 'Wildlife habitat' area identified on the Environmental Significance Overlay Maps (OM-004a-o): (a) protects and enhances the habitat of Endangered, Vulnerable and Near Threatened (EVNT) species and local species of significance; (b) incorporates siting and design measures to	No acceptable outcome is provided	·	Complies. The applicant's response satisfies PO5. The applicant states that "The tourist activities undertaken as part of the proposed development will be limited to

			1	
Perf	ormance outcomes	Acceptable outcomes	Complies	Comments
identifination identification identification economic adjaces according to the identification id	protect and retain identified ecological values and underlying ecosystem processes within or adjacent to the development site; maintains or enhances wildlife interconnectivity at a local and regional scale; and mitigates the impact of other forms of potential disturbance (such as presence of vehicles, pedestrian use, increased exposure to domestic animals, noise and lighting impacts) to protect critical life stage ecological processes (such as feeding, breeding or roosting). Development applications must y any EVNT species or their ts that may be affected by the sal. In particular, applications are notify and describe how the openent avoids adverse impacts ological processes within or ent to the development area. A supporting Ecological sment Report is prepared in dance with Planning Scheme 2 – Ecological Assessment			existing cleared areas of the site. No vegetation clearing is proposed as part of the development, with built improvements located to the north of the site in the vicinity of the existing Dwelling House." Reasonable and relevant conditions (atv speed limits, creek crossing restrictions) have been proposed.
Repor	ts.			
	ally secured offset areas		,	\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \
'Leg iden Envi Sigr (OM Lega is correquiand under impa ecolo all n	elopment within a ally secured offset area' tified on the ironmental sificance Overlay Maps -004a-o) or other known ally Secured Offset Area ensistent with the binding irements of the offset does not prejudice, ermine, or negatively	AO6 No acceptable outcome is provided.	n/a	Not applicable.

Performance outcomes	Acceptable outcomes	Complies	Comments
within the Legally Secured Offset Area.			
Note—A supporting Ecological Assessment Report is prepared in accordance with Planning Scheme Policy 2 – Ecological Assessment Reports.			
Protected areas			
PO7 Development within a 'Protected area' identified on the Environmental Significance Overlay Maps (OM-004a-o) is consistent with the values of the Protected Area and: (a) supports the inherent ecological and community values of the Protected Area asset; (b) maintains or enhances wildlife interconnectivity at a local and regional scale; and (c) does not prejudice, undermine, or negatively impact the inherent ecological values, including all naturally occurring native flora, fauna and their habitat within the Protected Area. Note—A supporting Ecological Assessment Report is prepared in accordance with Planning Scheme Policy 2 — Ecological Assessment	No acceptable outcome is provided	n/a	Not applicable.

Perf	ormance outcomes	Acceptable outcomes	Complies	Comments	
Eco	Ecological corridors and Habitat linkages				
POS	elopment located: in the Conservation zone, Emerging community zone, Recreation and open space zone, Rural zone or Rural residential zone;	AO8 No acceptable outcome is provided	•	Complies. The applicant's response satisfies PO8. The applicant states that "The tourist activities	
(b)	and within an 'Ecological corridor' or a 'Habitat linkage' identified on the Environmental Significance Overlay Maps (OM-004a-o)			undertaken as part of the proposed development will be limited to existing cleared areas of the site.	
coni corr	s not compromise the vision of habitat nectivity of the idor/linkage, having and to: the environmental values of the area of the site identified in the 'Ecological corridor' or 'Habitat linkage'; the environmental values of adjoining and nearby land within the 'Ecological corridor' or 'Habitat linkage':			No vegetation clearing is proposed as part of the development, with built improvements located to the north of the site within the vicinity of the existing Dwelling House.	
(c)	'Habitat linkage'; the extent of any modification proposed to the natural environment including (but not limited to) vegetation and topography;			The proposal retains the existing ecological corridors through	
(d)	the location and design of proposed improvements that may impact on the functions of the 'Ecological corridor' or 'Habitat linkage' including (but not limited to) buildings, structures, fences, lighting, vehicle movement areas and infrastructure services;			the site, including a number of creeks, to promote wildlife movement and habitat protection." Reasonable and relevant conditions (atv	
(e)	and the ability for the 'Ecological corridor' or			speed limits, creek crossing	

Performance outcomes	Acceptable outcomes	Complies	Comments
'Habitat linkage' to be enhanced to improve ecological connectivity.			restrictions) have been proposed.
Note—A supporting Ecological Assessment Report prepared in accordance with Planning Scheme Policy 2 – Ecological Assessment Reports may be appropriate to demonstrate compliance with PO8.			

Table 8.2.4.3B - Setback and buffer distances from waterways

Stream order	Setback and buffer from waterways
1	10 metres from top of high bank
2-4	25 metres from top of high bank
5 or more	50 metres from top of high bank

Note—The steam order of a 'waterway' is to be determined on a case by case basis.

9.4.2 Landscaping code

9.4.2.1 Application

This code applies where it is identified in the assessment benchmarks for assessable development and requirements for accepted development column of an assessment table in Part 5 of the planning scheme.

9.4.2.2 Purpose

- (1) The purpose of the Landscaping code is to ensure all development is landscaped to a standard that:
 - (a) complements the scale and appearance of the development;
 - (b) protects and enhances the amenity and environmental values of the site;
 - (c) complements and enhances the streetscape and local landscape character; and
 - (d) ensures effective buffering of incompatible land uses to protect local amenity.
- (2) The purpose of the code will be achieved through the following overall outcomes:
 - (a) Landscaping is a functional part of development design and is commensurate with the intended use;
 - (b) Landscaping accommodates the retention of existing significant on site vegetation where appropriate and practical;
 - (c) Landscaping treatments complement the scale, appearance and function of the development:
 - (d) Landscaping contributes to an attractive streetscape;
 - (e) Landscaping enhances the amenity and character of the local area;
 - (f) Landscaping enhances natural environmental values of the site and the locality;
 - (g) Landscaping provides effective screening both on site, if required, and between incompatible land uses:
 - (h) Landscaping provides shade in appropriate circumstances;
 - (i) Landscape design enhances personal safety and reduces the potential for crime and vandalism; and
 - (j) Intensive land uses incorporate vegetated buffers to provide effective screening of buildings, structures and machinery associated with the use.

9.4.2.3 Criteria for assessment

Table 9.4.2.3A—Landscaping code - For accepted development subject to requirements and assessable development

Performance outcomes	Acceptable outcomes	Complies	Comments
For accepted development s	ubject to requirements and asses	sable developmen	t
PO1 Development, other than in the Rural zone, includes landscaping that: (a) contributes to the landscape character of the Shire; (b) compliments the character of the immediate surrounds; (c) provides an appropriate balance between built and natural elements; and (d) provides a source of visual interest.	AO1 Development, other than in the Rural zone, provides: (a) a minimum of 10% of the site as landscaping; (b) planting in accordance with Planning Scheme Policy 6 - Landscaping and preferred plant species; (c) for the integration of retained significant vegetation into landscaping areas; (d) on-street landscaping works in accordance with the Design Guidelines set out in Section D9 Landscaping, of the Planning Scheme Policy 4 - FNQROC Regional Development Manual. Note—Where development exceeds a site cover of 90%, areas of landscaping may be provided above ground level to achieve a total supply of landscaping equivalent to 10% of the site area.	n/a	The subject land is in the Rural zone.

Performance outcomes	Acceptable outcomes	Complies	Comments
PO2 Development, other than in the Rural zone, includes	AO2 Development, other than in the Rural zone, includes a	n/a	Not applicable. The subject
landscaping along site frontages that: (a) creates an attractive	landscape strip along any site frontage: (a) with a minimum width of		land is in the Rural zone.
streetscape; (b) compliments the character of the immediate	2 metres where adjoining a car parking area; (b) with a minimum width of		
surrounds; (c) assists to break up and soften elements of built form;	1.5 metres in all other locations; and (c) in accordance with Planning Scheme		
(d) screen areas of limited visual interest or servicing;	Policy 6 - Landscaping and preferred plant species.		
(e) provide shade for pedestrians; and (f) includes a range and variety of planting.	Note—Where development is setback from a frontage less than 1.5 metres, the setback area is provided as a landscape strip		
PO3 Development includes landscaping and fencing along side and rear	AO3.1 Development provides landscape treatments along side and rear boundaries in	n/a	The subject land is in the Rural zone.
boundaries that:	accordance with Table		Table 9.4.3.2B
(a) screens and buffer land uses;	9.4.2.3B.		does not trigger additional side
(b) assists to break up and soften elements of built form;			and rear boundary landscape
(c) screens areas of limited visual interest;			treatments.
(d) preserves the amenity of sensitive land uses; and			
(e) includes a range and variety of planting.			

Performance outcomes	Acceptable outcomes	Complies	Comments
	AO3.2 Shrubs and trees provided in landscape strips along side and rear boundaries: (a) are planted at a maximum spacing of 1 metre; (b) will grow to a height of at least 2 metres; (c) will grow to form a screen of no less than 2 metres in height; and (d) are mulched to a minimum depth of 0.1 metres with organic mulch.	n/a	The subject land is in the Rural zone. Table 9.4.3.2B does not trigger additional side and rear boundary landscape treatments.
	AO3.3 Any landscape strip provided along a side or rear boundary is designed in accordance with Planning Scheme Policy 6 - Landscaping and preferred plant species.	n/a	The subject land is in the Rural zone. Table 9.4.3.2B does not trigger additional side and rear boundary landscape treatments.

Performance outcomes	Acceptable outcomes	Complies	Comments
PO4 Car parking areas are improved with a variety of landscaping that: (a) provides visual interest; (b) provides a source of shade for pedestrians; (c) assists to break up and soften elements; and (d) improves legibility.	ACCEPTABLE OUTCOMES AO4.1 Landscaping is provided in car parking areas which provides: (a) a minimum of 1 shade tree for every 4 parking spaces, or part thereof, where the car parking area includes 12 or more spaces; (b) a minimum of 1 shade tree for every 6 parking spaces, or part thereof, otherwise; and (c) where involving a car parking area in excess of 500m²: (i) shade structures are provided for	Complies	The applicant proposes landscape treatments that are commensurate with the rural use and setting of the subject land. The submission and approval of a landscaping plan will be conditioned.
	50% of parking spaces; and (ii) a minimum of 10% of the parking area as landscaping. Note—Where a shade structure is provided over part of a car parking area, shade tree planting is not required in this		
	AO4.2 Landscaping in car parking areas is designed in accordance with Planning Scheme Policy 6 - Landscaping and preferred plant species.	•	The proposed development will be conditioned to comply.
PO5 Landscaping areas include a range and variety of planting that: (a) is suitable for the intended purpose and local conditions; (b) contributes to the natural character of the Shire; (c) includes native species; (d) includes locally	AO5.1 Plant species are selected from the Plant Schedule in Planning Scheme Policy 6 - Landscaping and preferred plant species.	•	The proposed development will be conditioned to comply.

			•
Performance outcon	nes Acceptable outcomes	Complies	Comments
endemic species where practical; (e) does not include invasive plants of weeds.	and A minimum of 25% of (new and existing) plants is		The proposed development will be conditioned to comply.
PO6 Landscaping does impact on the one provision of infrastruand services to the Sh	cture underground water,	•	The proposed development will be conditioned to comply.
	AO6.2 Vegetation below or within 4 metres of overhead electricity lines and power poles has a maximum height of 3.5 metres at maturity.	•	The proposed development will be conditioned to comply.
	AO6.3 Vegetation adjoining an electricity substation boundary, at maturity, will have: (a) a height of less than 4 metres; and (b) no foliage within 3 metres of the substation boundary, unless the substation has a solid wall along any boundary.	n/a	Not applicable.
For assessable develo	pment		

Performance outcomes	Acceptable outcomes	Complies	Comments
PO7 Landscaping areas are designed to:	AO7 No acceptable outcome is provided.	•	The proposed development will be
(a) be easily maintained throughout the ongoing use of the site;	provided.		conditioned to comply.
(b) allow sufficient area and access to sunlight and water for plant growth;			
(c) not cause a nuisance to occupants of the site or members of the public; and			
(d) maintain or enhance the safety of pedestrians through the use of Crime Prevention Through Environmental Design principles.			

Table 9.4.2.3B—Side and rear boundary landscape treatments

able 9.4.2.3B—Side and rear boundary landscape treatments			
Location or use	Landscape Strip Minimum Width	Screen Fencing Minimum Height	Extent of treatment
Where car parking, servicing or manoeuvring areas adjoin a side or rear boundary	1 metre	Not applicable	To the extent these areas adjoin the boundary
Where involving a use other than a dwelling house on a site with a common boundary with land in the Low density residential zone, the Medium density residential zone or the Rural residential zone:	1.5 metres	1.8 metres	Along the common boundary.
Development for an industrial activity which has a common boundary with land not within the Industry zone	2 metres	1.8 metres	Along the common boundary
Development involving (a) Tourist park not in the Rural zone (b) Sales office (c) Multiple dwelling (d) Residential care facility; or (e) Dual occupancy	Not applicable	1.8 metres	Along all side and rear boundaries and between dwellings for a Dual occupancy.
Development involving (a) Tourist park in the Rural zone (b) Service station (c) Car wash; or (d) Utility installation	2 metres	Not applicable	Along all side and rear boundaries
For: (a) waste storage; (b) equipment; (c) servicing areas; and (d) private open space and site facilities associated with Caretaker's accommodation.	Not applicable	1.8 metres	To prevent visibility

Note—Where more than one landscape treatment is applicable to a development in the above table, the development is to provide a landscape treatment that satisfies all applicable minimum specifications.

9.4.5 Works, services and infrastructure code

9.4.5.1 Application

(1) This code applies to assessing development where it is identified in the assessment benchmarks for assessable development and requirements for accepted development column of an assessment table in Part 5 of the planning scheme.

9.4.5.2 Purpose

- (1) The purpose of the Works, services and infrastructure code is to ensure that all development is appropriately serviced by physical infrastructure, public utilities and services and that work associated with development is carried out in a manner that does not adversely impact on the surrounding area.
- (2) The purpose of the code will be achieved through the following overall outcomes:
 - (a) Development provides an adequate, safe and reliable supply of potable, fire-fighting and general use water in accordance with relevant standards;
 - (b) Development provides for the treatment and disposal of wastewater and ensures there are no adverse impacts on water quality, public health, local amenity or ecological processes;
 - (c) Development provides for the disposal of stormwater and ensures that there are no adverse impacts on water quality or ecological processes;
 - (d) Development connects to the road network and any adjoining public transport, pedestrian and cycle networks while ensuring no adverse impacts on the safe, convenient and efficient operation of these networks;
 - (e) Development provides electricity and telecommunications services that meet its desired requirements:
 - (f) Development is connected to a nearby electricity network with adequate capacity without significant environment, social or amenity impact;
 - (g) Development does not affect the efficient functioning of public utility mains, services or installations:
 - (h) Infrastructure dedicated to Council is cost effective over its life cycle;
 - (i) Work associated with development does not cause adverse impacts on the surrounding area; and
 - (j) Development prevents the spread of weeds, seeds or other pests.

9.4.5.3 Criteria for assessment

Table 9.4.5.3 - Works, services and infrastructure code - For accepted development subject to requirements and assessable development

Performance outcomes	Acceptable outcomes	Complies	Comments	
For accepted development subject to requirements and assessable development				
Water supply				

Performance outcomes	Acceptable outcomes	Complies	Comments
PO1 Each lot has an adequate volume and supply of water that: (a) meets the needs of users; (b) is adequate for firefighting purposes; (c) ensures the health, safety and convenience of the community; and (d) minimises adverse impacts on the receiving environment.	AO1.1 Development is connected to a reticulated water supply system in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual other than where located: (a) in the Conservation zone, Rural zone or Rural residential zone; and (b) outside a reticulated water supply service area.	n/a	The subject site is in the Rural zone and not within a reticulated water supply area.
	AO1.2 Development, where located outside a reticulated water supply service area and in the Conservation zone, Rural zone or Rural residential zone is provided with: (a) a bore or bores are provided in accordance with the Design Guidelines set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual; or (b) on-site water storage tank/s: (i) with a minimum capacity of 90,000L; (ii) fitted with a 50mm ball valve with a camlock fitting; and (iii) which are installed and connected prior to the occupation or use of the development.		The subject site is presently served by multiple ground water bores and a large dam.
Wastewater disposal			

Performance outcomes	Acceptable outcomes	Complies	Comments
PO2 Each lot provides for the treatment and disposal of effluent and other waste water that: (a) meets the needs of users; (b) is adequate for firefighting purposes; (c) ensures the health, safety and convenience of the community; and (d) minimises adverse impacts on the receiving environment.	AO2.1 Development is connected to a reticulated sewerage system in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual other than where located: (a) in the Conservation zone, Rural zone or Rural residential zone; and (b) outside a reticulated sewerage service area.	n/a	The subject site is in the Rural zone and not within a reticulated sewerage system.
	AO2.2 An effluent disposal system is provided in accordance with ASNZ 1547 On-Site Domestic Wastewater Management (as amended) where development is located: (a) in the Conservation zone, Rural zone or Rural residential zone; and (b) outside a reticulated sewerage service area.	•	Compliant on-site effluent disposal arrangements will be provided.
Stormwater infrastructure	9		
PO3 Stormwater infrastructure is designed and constructed to collect and convey the design storm event to a lawful point of discharge in a manner that mitigates impacts on life and property.	AO3.1 Where located within a Priority infrastructure area or where stormwater infrastructure is available, development is connected to Council's stormwater network in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual.	n/a	The subject land is not within a priority infrastructure area.

Performance outcomes	Acceptable outcomes	Complies	Comments
	AO3.2 On-site drainage systems are constructed: (a) to convey stormwater from the premises to a lawful point of discharge; and (b) in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual.		There will be no significant alteration in established stormwater arrangements.
Electricity supply			
Each lot is provided with an adequate supply of electricity	The premises: (a) is connected to the electricity supply network; or (b) has arranged a connection to the transmission grid; or (c) where not connected to the network, an independent energy system with sufficient capacity to service the development (at near average energy demands associated with the use) may be provided as an alternative to reticulated electricity where: (i) it is approved by the relevant regulatory authority; and (ii) it can be demonstrated that no air or noise emissions; and (iii) it can be demonstrated that no adverse impact on visual amenity will occur.		The subject site is serviced with a connection to the electricity grid.
Telecommunications infrast	tructure		

Performance outcomes	Acceptable outcomes	Complies	Comments
PO5 Each lot is provided with an adequate supply of telecommunication infrastructure	AO5 Development is provided with a connection to the national broadband network or telecommunication services.	•	The subject site is serviced with a connection to telecommunication services.
Existing public utility ser	vices		
PO6 Development and associated works do not affect the efficient functioning of public utility mains, services or installations.	Public utility mains, services are relocated, altered or repaired in association with the works so that they continue to function and satisfy the relevant Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual.	•	The development will be conditioned to comply.
Excavation or filling			
PO7 Excavation or filling must not have an adverse impact on the: (a) streetscape; (b) scenic amenity; (c) environmental values;	AO7.1 Excavation or filling does not occur within 1.5 metres of any site boundary.	n/a	Significant filling or excavation is not proposed. Minor earthworks will be associated with the proposed building works.
(d) slope stability; (e) accessibility; or (f) privacy of adjoining premises.	AO7.2 Excavation or filling at any point on a lot is to be no greater than 1.5 metres above or below natural ground level.	n/a	Significant filling or excavation is not proposed. Minor earthworks will be associated with the proposed building works.

Performance outcomes	Acceptable outcomes	Complies	Comments
	AO7.3 Earthworks batters: (a) are no greater than 1.5 metres in height; (b) are stepped with a minimum width 2 metre berm; (c) do not exceed a maximum of two batters and two berms (not greater than 3.6 metres in total height) on any one lot; (d) have a slope no greater than 1 in 4; and (e) are retained.	n/a	Significant filling or excavation is not proposed. Minor earthworks will be associated with the proposed building works.
	AO7.4 Soil used for filling or spoil from excavation is not stockpiled in locations that can be viewed from: (a) adjoining premises; or (b) a road frontage, for a period exceeding 1 month from the commencement of the filling or excavation.	n/a	Significant filling or excavation is not proposed. Minor earthworks will be associated with the proposed building works.
	AO7.5 All batters and berms to be constructed in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 - FNQROC Regional Development Manual.	n/a	Significant filling or excavation is not proposed. Minor earthworks will be associated with the proposed building works.
	AO7.6 Retaining walls have a maximum height of 1.5 metres and are designed and constructed in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development manual.	n/a	Significant filling or excavation is not proposed. Minor earthworks will be associated with the proposed building works.

Performance outcomes	Acceptable outcomes	Complies	Comments
	AO7.7 Excavation or filling at any point on a lot is to include measures that protect trees at the foot or top of cut or fill batters by the use of appropriate retaining methods and sensitive earth removal or placement and in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development manual.	n/a	Significant filling or excavation is not proposed. Minor earthworks will be associated with the proposed building works.
For assessable developmen	nt		
Transport network			
PO8 The development has access to a transport network of adequate standard to provide for the safe and efficient movement of vehicles, pedestrians and cyclists.	AO8.1 Vehicle access, crossovers, road geometry, pavement, utilities and landscaping to the frontage/s of the site are designed and constructed in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development manual.	•	The development will be conditioned to comply.
	AO8.2 Development provides footpath pavement treatments in accordance with Planning Scheme Policy 9 – Footpath Paving.	n/a	Not applicable.
Public infrastructure			
PO9 The design, construction and provision of any infrastructure that is to be dedicated to Council is cost effective over its life cycle and incorporates provisions to minimise adverse impacts.	AO9 Development is in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 - FNQROC Regional Development Manual.	•	The development will be conditioned to comply.
Stormwater quality			

Performance outcomes	Acceptable outcomes	Complies	Comments
PO10 Development has a non-worsening effect on the site and surrounding land and is designed to: (a) optimise the interception, retention and removal of waterborne pollutants, prior to the discharge to receiving waters; (b) protect the environmental values of waterbodies affected by the development, including upstream, on-site and downstream waterbodies; (c) achieve specified water quality objectives; (d) minimise flooding; (e) maximise the use of natural channel design principles; (f) maximise community benefit; and (g) minimise risk to public safety.	AO10.1 The following reporting is prepared for all Material change of use or Reconfiguring a lot proposals: (a) a Stormwater Management Plan and Report that meets or exceeds the standards of design and construction set out in the Queensland Urban Drainage Manual (QUDM) and the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development Manual; and (b) an Erosion and Sediment Control Plan that meets or exceeds the Soil Erosion and Sedimentation Control Guidelines (Institute of Engineers Australia), including: (i) drainage control; (ii) erosion control; (iii) sediment control; and (iv) water quality outcomes.		The site is located in the Rural Zone. The proposed development involves a small scale tourist use with a minimal footprint. The proposed development is not considered to be of sufficient magnitude to alter existing stormwater flows.

Performance outcomes	Acceptable outcomes	Complies	Comments
	For development on land greater than 2,500m² or that result in more than 5 lots or more than 5 dwellings or accommodation units, a Stormwater Quality Management Plan and Report prepared and certified by a suitably qualified design engineer (RPEQ) is prepared that demonstrates that the development: (a) meets or exceeds the standards of design and construction set out in the Urban Stormwater Quality Planning Guideline and the Queensland Water Quality Guideline; (b) is consistent with any local area stormwater water management planning; (c) accounts for development type, construction phase, local climatic conditions and design objectives; and (d) provides for stormwater quality treatment measures reflecting land use constraints, such as soil type, landscape features (including landform), nutrient hazardous areas, acid sulfate soil and rainfall erosivity.		The site is located in the Rural Zone. The proposed development involves a small scale tourist use with a minimal footprint. The proposed development is not considered to be of sufficient magnitude to alter existing stormwater flows.

Performance outcomes	Acceptable outcomes	Complies	Comments
PO11 Storage areas for stormwater detention and retention: (a) protect or enhance the environmental values of receiving waters; (b) achieve specified water quality objectives; (c) where possible, provide for recreational use; (d) maximise community benefit; and (e) minimise risk to public safety.	AO11 No acceptable outcome is provided.	•	A large dam is established on site.
Excavation or filling			
PO12 Traffic generated by filling or excavation does not impact on the amenity of the surrounding area.	AO12.1 Haul routes used for transportation of fill to or from the site only use major roads and avoid residential areas.	n/a	Significant filling or excavation is not proposed. Minor earthworks will be associated with the proposed building works.
	AO12.2 Transportation of fill to or from the site does not occur: (a) within peak traffic times; and (b) before 7am or after 6pm Monday to Friday; (c) before 7am or after 1pm Saturdays; and (d) on Sundays or Public Holidays.	n/a	Significant filling or excavation is not proposed. Minor earthworks will be associated with the proposed building works.

Performance outcomes	Acceptable outcomes	Complies	Comments
PO13 Air pollutants, dust and sediment particles from excavation or filling, do not cause significant environmental harm or nuisance impacts.	AO13.1 Dust emissions do not extend beyond the boundary of the site.	n/a	Significant filling or excavation is not proposed. Minor earthworks will be associated with the proposed building works.
	AO13.2 No other air pollutants, including odours, are detectable at the boundary of the site.	n/a	Significant filling or excavation is not proposed. Minor earthworks will be associated with the proposed building works.
	AO13.3 A management plan for control of dust and air pollutants is prepared and implemented.	n/a	Significant filling or excavation is not proposed. Minor earthworks will be associated with the proposed building works.
PO14 Access to the premises (including driveways and paths) does not have an adverse impact on: (a) safety; (b) drainage; (c) visual amenity; and (d) privacy of adjoining premises.	ACCESS to the premises (including all works associated with the access): (a) must follow as close as possible to the existing contours; (b) be contained within the premises and not the road reserve, and (c) are designed and constructed in accordance with the Design Guidelines and Specifications set out in the Planning Scheme Policy 4 – FNQROC Regional Development manual.	n/a	Significant filling or excavation is not proposed. Minor earthworks will be associated with the proposed building works.
Weed and pest managem	ent		

Performance outcomes	Acceptable outcomes	Complies	Comments
PO15 Development prevents the spread of weeds, seeds or other pests into clean areas or away from infested areas.	AO15 No acceptable outcome is provided.	•	The development will be conditioned to comply.
Contaminated land			
PO16 Development is located and designed to ensure that users and nearby sensitive land uses are not exposed to unacceptable levels of contaminants	AO16 Development is located where: (a) soils are not contaminated by pollutants which represent a health or safety risk to users; or (b) contaminated soils are remediated prior to plan sealing, operational works permit, or issuing of building works permit.	•	The subject land is not known to be contaminated.
Fire services in developm	nents accessed by common pr	ivate title	
PO17 Fire hydrants are located in positions that will enable fire services to access water safely, effectively and efficiently.	AO17.1 Fire hydrants are located in accessways or private roads held in common private title at a maximum spacing of: (a) 120 metres for residential development; and (b) 90 metres for any other development.	n/a	Not applicable.
	AO17.2 Fire hydrants are located at all intersections of accessways or private roads held in common private title.	n/a	Not applicable.